



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 fax

www.sjwatertest.com
NJ DEP Certified Lab #080946

Loudenslager Elementary School

100 Baird Avenue
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 06/10/2017 10:39 - 11:00

Date & Time Analyzed: 06/14/2017 03:21 - 04:07

Date & Time Analyzed: 06/15/2017 16:10 - 17:13

Date & Time Analyzed: 06/16/2017 15:42


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
L-DW-01	675	15.5
L-DW-03	9.16	15.5
L-DW-14	5.43	15.5
L-DW-16	20.6	15.5
L-DW-12	<2.00	15.5
L-DW-17	<2.00	15.5
L-DW-20	15.6	15.5
L-DW-05	<2.00	15.5
L-DW-10	14.1	15.5
L-DW-09	2.54	15.5
L-DW-07	44.5	15.5
L-DW-04	<2.00	15.5
L-DW-19	<2.00	15.5
L-DW-18	<2.00	15.5


Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #080006

Loudenslager Elementary School

100 Baird Avenue
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 07/10/2017 09:36 - 09:50

Date & Time Analyzed: 07/10/2017 01:37 - 01:57

Sample Location	Sample Result	Action Level
L-DW-16(Flushed)	<2.00	15.5
L-DW-20(Flushed)	<2.00	15.5
L-DW-07(Flushed)	5.52	15.5
L-DW-01(Flushed)	18.9	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

7/17/17
Date