



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NELAP Certified Lab #08096

**Paulsboro Board of Education
Bus Garage/Maintenance Shop/Sports Fields**

670 North Delaware Street
Paulsboro, NJ 08066

Results of Lead Analysis

06/10/2017 06:55 - 07:02

Date & Time Analyzed: 06/14/2017 02:27 - 03:14

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
BG-DW-01	119	15.5
BG-DW-03	5.56	15.5
BG-DW-05	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

7/6/17

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #000000

**Paulsboro Board of Education
Bus Garage/Maintenance Shop/Sports Fields**

670 North Delaware Street
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 07/10/2017 08:52

Date & Time Analyzed: 07/10/2017 00:31


Sample Location	Sample Result	Action Level
BG-DW-01 (Flushed)	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.



Mark J. Riether, Laboratory Director

7/14/17
Date