



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterlab.com
NJ DEP Certified Lab #080946

Billingsport Early Childhood Center

441 Nassau Avenue
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 06/10/2017 09:44 - 10:26

Date & Time Analyzed: 06/16/2017 14:56 - 20:00

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
B-DW-01	333	15.5
B-DW-08	6.52	15.5
B-DW-10	3.34	15.5
B-DW-11	<2.00	15.5
B-DW-15	165	15.5
B-DW-12	2.86	15.5
B-DW-16	35.5	15.5
B-DW-14	<2.00	15.5
B-DW-13	<2.00	15.5
B-DW-17	17.7	15.5
B-DW-06	<2.00	15.5
B-DW-04	<2.00	15.5
B-DW-35	2.62	15.5
B-DW-19	<2.00	15.5
B-DW-18	<2.00	15.5
B-DW-03	<2.00	15.5
B-DW-02	<2.00	15.5
B-DW-21	<2.00	15.5
B-DW-22	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #00006

Billingsport Early Childhood Center

441 Nassau Avenue
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 06/10/2017 09:44 - 10:26

Date & Time Analyzed: 06/16/2017 14:56 - 20:00


Sample Location	Sample Result	Action Level
B-DW-24	13.0	15.5
B-DW-25	8.07	15.5
B-DW-27	2.56	15.5
B-DW-28	<2.00	15.5
B-DW-30	8.01	15.5
B-DW-31	<2.00	15.5
B-DW-33	4.47	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #100000

Billingsport Early Childhood Center

441 Nassau Avenue
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 07/10/2017 09:01 - 09:23

Date & Time Analyzed: 07/10/2017 00:51 - 01:30

Sample Location	Sample Result	Action Level
B-DW-15 (Flushed)	<2.00	15.5
B-DW-16(Flushed)	7.09	15.5
B-DW-17(Flushed)	<2.00	15.5
B-DW-01(Flushed)	5.36	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

7/17/17

Date

HORIZON ENVIRONMENTAL GROUP, INC.

P.O. Box 316
Thorofare, NJ 08086

Phone: 856-848-0800
Fax: 856-848-0838

November 26, 2018

Mr. Jack Henderson
Paulsboro Board of Education
662 North Delaware Street
Paulsboro, NJ 08066

Reference: Billingsport Early Childhood Center
Lead in Water Testing

Dear Mr. Henderson:

Pursuant to your request, collection and analysis of water samples from the water fountain in Room 7 at Billingsport Early Childhood Center have been completed. The samples were collected on Friday, November 9, 2018, by personnel from Horizon Environmental Group, Inc., and submitted for analysis for the presence of lead using inductively coupled plasma mass spectrometry (ICP-MS) in accordance with USEPA Method 200.8. The results of the analyses of the samples are as follows:


Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
B-DW-34	Room 7 (Water Fountain)	ND	1.00
B-DW-35	BLANK	ND	1.00

Note: "µg/L" equals micrograms per liter which is equivalent to parts per billion (ppb)

Please note that the result of each sample is less than the "action level" of 15 µg/L (ppb), as established by the United States Environmental Protection Agency and adopted by the State of New Jersey. The "action level" of 15 µg/L (ppb) does not necessarily signal a violation, but would trigger additional monitoring, maintenance, treatment and/or mitigation requirements. All laboratory analysis was performed by the trained staff at EMSL Analytical, Inc. in Cinnaminson, New Jersey and a copy of the analysis document is attached.

If you have any questions or need more information, please do not hesitate to contact us at (856) 848-0800.

Sincerely,
HORIZON ENVIRONMENTAL GROUP, INC.



Steven J. Flanigan
Vice President



HORIZON ENVIRONMENTAL GROUP, INC.

P.O. Box 316
Thorofare, NJ 08086

Phone: 856-848-0800
Fax: 856-848-0838

August 20, 2019

Mr. Jack Henderson
Paulsboro Board of Education
662 North Delaware Street
Paulsboro, NJ 08066

Reference: Billingsport Early Childhood Center
Lead in Water Testing

Dear Mr. Henderson:

Pursuant to your request, collection and analysis of a water sample from the water fountain in the hallway near Room 1 at the Billingsport Early Childhood Center have been completed. The sample, along with a blank, was collected on Tuesday, August 13, 2019, by personnel from Horizon Environmental Group, Inc., and submitted for analysis for the presence of lead using inductively coupled plasma mass spectrometry (ICP-MS) in accordance with USEPA Method 200.8. The results of the analyses of the samples are as follows:

Sample No.	Location	Lead Concentration (µg/L)	Reporting Limit (µg/L)
B-DW-03	Hall by Room 1 (Water Fountain)	ND	1.00
B-BLANK-190813-01	BLANK	ND	1.00

Note: "µg/L" equals micrograms per liter which is equivalent to parts per billion (ppb)

Please note that the result of each sample is less than the "action level" of 15 µg/L (ppb), as established by the United States Environmental Protection Agency and adopted by the State of New Jersey. The "action level" of 15 µg/L (ppb) does not necessarily signal a violation, but would trigger additional monitoring, maintenance, treatment and/or mitigation requirements. All laboratory analysis was performed by the trained staff at EMSL Analytical, Inc. in Cinnaminson, New Jersey and a copy of the analysis document is attached.

If you have any questions or need more information, please do not hesitate to contact us at (856) 848-0800.

Sincerely,
HORIZON ENVIRONMENTAL GROUP, INC.

Steven J. Flanigan
Vice President