

Water Testing Results - Burns High School

Action Level is 20 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen		8/5/2016	40.7
Drinking Fountain in Weight Room		8/5/2016	0.181
Drinking Fountain in Boy's Locker Room		8/5/2016	2.07
Drinking Fountain in Girl's Locker Room		8/5/2016	1.63
Drinking Fountain Between Locker Rooms		8/5/2016	ND
Room 41		8/5/2016	3.76
Booster Room Drinking Fountain		8/5/2016	ND
Drinking Fountain Front Hall		8/5/2016	2.59
Drinking Fountain Center Hall		8/5/2016	3.47
Drinking Fountain South Hall		8/5/2016	3.26
Drinking Fountain West Hall		8/5/2016	1.05
Staff Room		8/5/2016	2.82

ND = Non Detect - Lead level is below the set detection limits of 0.103 ppb

Lab Sheets reporting in mg/L - Convert mg/L to ppb by Multiplying by 1,000