

JACKS CREEK ELEMENTARY SCHOOL

ASBESTOS

MANAGEMENT PLAN

TABLE OF CONTENTS

<u>Page No.</u>	<u>Contents</u>	<u>TAHERA Form No.</u>
	A. Table of Contents	4.0
1.	B. Transmittal Sheet	1.0
2.	C. Cover Sheet	2.0
3.	D. Assurances	3.0
4.	E. School Building List	5.0
	F. School Information Form	
	Jacks Creek Elementary School	
99.	A. School Information Sheet	6.1
100.	B. Homogeneous Area Summary	6.2
101-105.	C. Homogeneous Area Drawing	6.3
106-108.	D. Follow-up Action	6.6
109-114.	E. Drawing of ACBM To Remain	6.7
115.	F. Operations And Maintenance	6.8
	G. Appendix I	
169-170.	1. Operation And Maintenance Procedures	7.0
171-172.	2. Laboratory Accreditation Statement	8.0
	3. Bulk Sample Analysis	
173-179.	a. Chester County High School	
180-184.	b. East Chester Elementary School	
185-189.	c. North Chester Elementary School	
	4. Accreditation Certificates	
190-191.	a. Inspectors	
192-193.	b. Management Planeers	
194.	c. Cards	
195-196.	5. Copy of Notifications	
	H. Appendix II	
197-203.	1. Employee Training Forms	11.0
	2. Cleaning Records	13.0
204.	a. Chester County High School	
205.	b. Chester County Junior High School	
206.	c. East Chester Elementary School	
207.	d. Jacks Creek Elementary School	
208.	e. North Chester Elemetary School	
209.	f. West Chester Elementary School	

LEA: Chester County LEA NO.: 120

Date: 9/30/88

TRANSMITTAL SHEET/AHERA SUBMITTALS

1. DEFERRAL REQUEST

SUBMISSION: Original ☐ Resubmittal ☐

STATE REVIEW

Remarks: _____

No Exceptions Taken ☐

Returned for Reasons Stated ☐

2. MANAGEMENT PLAN

SUBMISSION: Original ☒ Resubmittal ☐ New Building ☐

STATE REVIEW

Remarks: _____

No Exceptions Taken ☐

Returned for Reasons Stated ☐

3. MANAGEMENT PLAN PROGRESS REPORT No. _____ Dated _____

SUBMISSION: Original ☐ Resubmittal ☐

STATE REVIEW

Remarks: _____

No Exceptions Taken ☐

Returned for Reasons Stated ☐

Reviewer's Signature _____

Dated: _____

LEA: Chester Co. Board of Education LEA NO.: 120

Address: P.O. Box 327

Henderson, TN 38340

County: Chester County

Superintendent: Dr. Kathy Coatney Mays

Date: 9/30/88

COVER SHEET

No person or firm shall offer to perform or be hired to perform as professionals the services of inspection, preparation of management plans, designing of response actions, or supervising of response actions except as properly accredited under the provisions of The Asbestos Hazard Emergency Response Act of 1986, Public Law 99 - 519, and Code of Federal Regulations Title 40, Part 763 (AHERA). The U. S. Environmental Protection Agency and the State of Tennessee recommend those persons or firms performing as professionals be registered under the registration laws of the State of Tennessee or a state which has reciprocity with the State of Tennessee. Such professionals should be independent practitioners and should have no financial or other interest in contractors, subcontractors, manufacturers, or jobbers under their jurisdiction where direct conflict of interest could occur, except as permitted.

An employee of a State or local public or private education agency (LEA) may provide the services of inspection or preparation of the management plans for their respective LEA's facilities, provided that person is properly accredited under the AHERA laws and regulations.

The signatures hereon attest to the above statement and certify that it is the intent of the signatories to carry out all other provisions of the AHERA laws and regulations.

MANAGEMENT PLANNER (MP) (Attach copy of accreditation certificate in Appendix)

Name: Gene Cain Accreditation No.: 418
Firm/LEA: Madison County Board of Education
Address: 701 South Highland Ave. Training Agency: Georgia Institute of Technology
City/State/Zip: Jackson, TN 38301 Training Course: Managing Asbestos in Buildings
Telephone: 901-423-0270 Course Date: March 23-25, 1988
Signature: *Gene Cain*
Dated: 9/30/88

LOCAL EDUCATION AGENCY (LEA) DESIGNATED PERSON

Name: Gene Cain Training Agency: Georgia Tech
Address: 9 Rutherford Ave. Training Course: Inspecting & Managing Asbestos
City/State/Zip: Jackson, TN 38301 Training Dates: March 21-25, 1988
Telephone: 901-427-6428 Total Hours: 40
LEA Designated Person's Signature: *Gene Cain* LEA Superintendent's Signature: *Kathy Coatney Mays*
Dated: 9/30/88 Dated: September 30, 1988

(Management)
(Planner's)
(Seal)

LEA: Chester Co. Board of Edu. LEA NO.: 120
Address: P.O. Box 327
Henderson, TN 38340
Superintendent: Dr. Kathy Coatney Mays
Telephone: 901-989-5134
Date: 9/30/88

ASSURANCES

This AHERA Management Plan was developed and has been submitted pursuant to the Asbestos Hazard Emergency Response Act of 1986, Public Law 99-519; and the United States Environmental Protection Agency Rule: Asbestos Containing Material in Schools, 40 CFR Part 763; and the undersigned does hereby certify that the Local Education Agency (LEA) indicated below has and will ensure the following:

1. The activities of any persons who perform inspections, re-inspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Part 763 and other State rules and requirements.
2. All custodial and maintenance employees are properly trained as required in Part 763 and all other applicable Federal and State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule or applicable State regulations).
3. All workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities, that are planned or in progress.
4. All short term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of asbestos-containing building materials (ACBM) and suspected ACBM assumed to be asbestos-containing materials (ACM).
5. All warning labels are posted in accordance with Section 763.95.
6. All management plans are available for inspection and notification of such availability has been provided as specified in the AHERA regulations under Section 763.93(g).
7. The undersigned person designated by the LEA pursuant to Section 763.84(g)(1) has received adequate training as stipulated in Section 763.84(g)(2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship between the Management Planner and other accredited persons performing AHERA activities.

Signed: _____

LEA Designated Person, pursuant
to 40 CFR 763.93(i) and 763.84

Date: _____

9/30/88

Typed Name: Gene Cain

LEA: Chester Co. Board of Education LEA NO.: 120

Date: 9/30/88

SCHOOL BUILDING LIST

List all schools and separate buildings:

D.O.E. SCHOOL NUMBER	SCHOOL NAME OR BUILDING NAME	ADDRESS	CITY	ZIP CODE	ACBM F NF		NO ACBM
120 0005	Chester Co. High. Hwy. 100 East, Henderson, TN 38340				X	X	
126 0010	Chester Co. Jr. High, Hwy. 100 East, Henderson, TN 38340					X	
	Bus Shop, Hwy. 100 East, Henderson, TN 38340						X
120 0015	East Chester Elem., Hwy. 100 East, Henderson, TN 38340					X	
120 0025	Jack's Creek Elem., General Delivery, Henderson, TN 38347					X	
120 0028	North Chester Elem., Luray Ave., Henderson, TN 38340				X	X	
0030	West Chester Elem., Hwy. 100 West, Henderson, TN 38340					X	

LEGEND:

F = Friable

NF = NonFriable

ACBM = Asbestos-Containing Building Material

D.O.E = Department of Education

LEA: Chester Co. Board of Education LEA NO.: 120

Date: 9/30/88

1. BUILDING STATISTICS

Date Built	Area Name, Wing Addition, etc.	Use	Total Area (Square Feet)
8-57	Jacks Creek	School	14,638
7-74	3 Portables		2,592

2. STRUCTURAL SYSTEMS

Walls:	Floors:	Roof:	Foundation:
<input checked="" type="checkbox"/> Masonry/Concrete	<input type="checkbox"/> Wood	<input type="checkbox"/> Wood	<input checked="" type="checkbox"/> Slab-on-grade
<input type="checkbox"/> Steel	<input checked="" type="checkbox"/> Concrete	<input type="checkbox"/> Concrete	<input type="checkbox"/> Crawlspace
<input type="checkbox"/> Wood	<input type="checkbox"/> Steel	<input checked="" type="checkbox"/> Steel	<input type="checkbox"/> Basement
<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other

Notes (Explain Other): _____

3. MECHANICAL SYSTEMS

Heating:		Cooling:	
<input type="checkbox"/> Central HVAC	<input type="checkbox"/> Wall Electric	<input type="checkbox"/> Central HVAC	<input type="checkbox"/> Window Units
<input checked="" type="checkbox"/> Radiator	<input type="checkbox"/> Other	<input type="checkbox"/> Wall Electric	<input type="checkbox"/> Other

Notes (Explain Other): Propane Gas Heaters**4. ARCHITECTURAL FINISHES**

Ceiling:	Flooring:	Walls:
<input type="checkbox"/> Lathe and Plaster	<input checked="" type="checkbox"/> Vinyl Tile	<input type="checkbox"/> Lathe and Plaster
<input type="checkbox"/> Gypsum Board	<input type="checkbox"/> Carpet	<input type="checkbox"/> Gypsum Board
<input type="checkbox"/> Acoustical Finish	<input type="checkbox"/> Wood	<input checked="" type="checkbox"/> Masonry
<input checked="" type="checkbox"/> Tile	<input type="checkbox"/> Unfinished	<input type="checkbox"/> Wood/Paneling
<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other

Notes (Explain Other): _____

5. SUMMARY OF DOCUMENTS REVIEWED

<input checked="" type="checkbox"/> Floor Plans	<input type="checkbox"/> Sections	<input type="checkbox"/> Past Abatement Projects
<input checked="" type="checkbox"/> Mechanical Drawings	<input type="checkbox"/> As Built Drawings	<input type="checkbox"/> Past Abatement Specs.
<input checked="" type="checkbox"/> Specifications	<input type="checkbox"/> Sampling Reports	<input type="checkbox"/> Past Abatement Drawing
<input type="checkbox"/> Finish Schedules	(In-house)	<input type="checkbox"/> Past Surveys

6. INSPECTION INFORMATION (Attach copy of certificate for each Inspector.)Date of Inspection: 7-19-88

Inspection

Team Members

Signature

Accreditation

Number/State

Affiliation

Gene Cain477-GeorgiaLEA: Chester CountyLEA NO.: 120Date: 9/30/88

1.

HA No.	Material Description	Material Type (T, S or M)	BIA No.s Included in HA	Sample No.s Taken in HA	HA Drawing No.
1	Vinyl Asbestos Tile	M			0025-1
2	Vinyl Asbestos Tile	M			0025-2
3	Vinyl Asbestos Tile	M			0025-3
4	Vinyl Asbestos Tile	M			0025-4
	Ceiling Tile	M			All

Through
Out

2.

HA No.	ACBM				No ACBM	Total Quantity (Show Units)	Exposure Considerations								Assessment Category
	Confirmed F	NF	Assumed F	NF			A	B	C	D	E	F	G	H	
1				X		6401 Sq. Ft.	1	1	1	1	3	3	2	4	5
2				X		42 Sq. Ft.	1	1	1	1	3	3	2	4	5
3				X		959 Sq. Ft.	1	1	1	1	3	3	2	4	5
4				X		1512 Sq. Ft.	1	1	1	1	3	3	2	4	5
				X		15,000 Sq. Ft.	1	1	1	3	3	3	5	5	5

Through
Out

Exposure Considerations (A through F, rate 1 to 5 with 5 being worst):

A. Deterioration
B. Physical Damage
C. Water Damage
D. Activity/Vibration
E. Exposure
F. Accessibility

G. Length of Exposure
1. 1 hr./week
2. 5 hr./week
3. 10 hr./week
4. 20 hr./week
5. 40 hr./week

H. Exposure Population
1. Maintenance
2. Maint., Custodial
3. Maint., Cust., Faculty
4. Maint., Cust., Fac., Students
5. Maint., Cust., Fac., Stud., Public

Assessment Categories:


1. Damaged/Significantly damaged TSI
2. Damaged friable SURFACING ACM
3. Significantly damaged friable SURFACING ACM
4. Damaged or significantly damaged friable MISCELLANEOUS ACM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or friable suspected ACBM

Legend:


HA = Homogeneous Area
T = Thermal System Insulation
S = Surfacing
M = Miscellaneous
BIA = Building Inspection Area
(Number assigned by Inspector)

LEA: Chester CountyLEA NO.: 120Date: 9/30/88

Identify limits of homogeneous area and sample locations.

HOMOGENEOUS AREA ASCALE 1"=20' VINYL ASBESTOS
FLOOR TILELEA: Chester CountyLEA NO.: 120Date: 9/30/88

Identify limits of homogeneous area and sample locations.



HOMOGENEOUS AREA B

SCALE 1"=20'


N

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.



HOMOGENEOUS AREA C


SCALE 1"=10'

 VYNL ASBESTOS
FLOOR TILE

LEA: Chester County LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.



HOMOGENEOUS AREA D

SCALE 1" = 20'

 VINYL ASBESTOS
FLOOR TILE



LEA: Chester County

LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.

S



HOMOGENEOUS AREA

SCALE 1"=20'

N

LEA: Chester County LEA NO.: 120

Date: 9/30/88

1. Recommended by Management Planner

HA No.	ACBM Description	Management Planner Recommended Response Action	LEA Selected Response Action*	Schedule Dates Start	Complete
1	Vinyl Asbestos Tile	A-B	A-B	July 1989	Until Removed
2	Vinyl Asbestos Tile	A-B	A-B	July 1989	Until Removed
3	Vinyl Asbestos Tile	A-B	A-B	July 1989	Until Removed
4	Vinyl Asbestos Tile	A-B	A-B	July 1989	Until Removed
	Ceiling Tile	A-B	A-B	July 1989	Until Removed

Through.
Out

2. Management Planner's method for selection of response actions:

Response actions based on hazard ranking required by AHERA Section 763.90

*If different than recommended action, explain:

Appropriate Response Actions:

A. Institute Preventative Measures
B. O & M Program
C. Repair
D. Encapsulate

E. Enclose
F. Remove
G. Isolate
H. Other (Explain)

LEA: Chester County LEA NO.: 120
Date: 9-30-88

(Use separate sheet for each response action listed on Form TAHERA 6.4)

1. RESPONSE ACTION:

- ☐ Institute Preventative Measures
- ☒ Operations and Maintenance Program
- ☐ Repair
- ☐ Isolate

- ☐ Enclose
- ☒ Remove
- ☐ Encapsulate
- ☐ Other

Notes (Explain Other): Ceiling Tile

2. DETAILED DESCRIPTION:

Incorporate these areas/materials into an Operations and Maintenance Program until major renovation or demolition requires removal under NESIAPS or until hazard assessment factors change.

3. LOCATIONS (List all HA No.s, BIA No.s or attach Drawing):

Throughout

4. REASONS (Give reason for selecting response action):

This material is not very friable, is in good condition and is not easily accessible, and does not present a health hazard in its present condition.

5. SCHEDULE (Starting and completion dates for response action):

Begin May 9, 1989 and continue as long as this material remains in the building.

6. RESOURCES NEEDED (Additionally, list funding sources, if known):

Include in general Operations and Maintenance Program with removal costs estimated at \$3.00 - \$4.50 per square foot.

FOLLOW-UP ACTIONS

1. **NOTIFICATION PLAN** (Describe method of Notification and include dated copy of actual Notifications, meeting minutes, newspaper articles, etc. in Appendix):

All parent's, teacher's, employee's organizations and school groups will be informed in writing of the location of the ACM and the location of the Management Plan. The Management Plan will go into effect July 9, 1989. The periodic surveillance will be in January of 1990 and each six months thereafter. In three years after July 9, 1989, all schools will be reinspected as described in AHERA 763.85 (b).

2. **PERIODIC SURVEILLANCE PLAN:** LEA shall perform Periodic Surveillance at least every six (6) months from date of Management Plan Implementation (Report surveillance on Form TAHERA 9.0).

3. **REINSPECTION PLAN:** The requirements of a Reinspection Plan are described in Paragraph 763.85(b) of AHERA and shall include performance by an accredited inspector; frequency (at least every three (3) years); address all friable and nonfriable, known or assumed ACBM; visual reinspection and reassessment; touching of material to determine changes of condition; identification of homogeneous areas where material has become friable since the last inspection; sampling of areas assumed to contain ACBM; reassessment of areas where condition of materials has changed; recording of dates of reinspection; changes of conditions of materials; exact sample locations; manner used to determine sampling locations; and names and signatures of persons making the reinspection, taking samples and reassessing the materials, accreditation numbers and states of accreditation.

4. **PROGRESS REPORTS:** Progress Reports on Management Plan Implementation are to be submitted to the State AHERA Designated Person no later than July 9 of each year beginning 1990. These reports are to include each completed response action, each response action in progress, how these response action schedules compare with the Management Plan schedule, results of Reinspections and Surveillances, a summary of Operations and Maintenance activities and resources needed to continue Implementation of the Management Plan. Copies of the Progress Reports should be placed in the Appendix to the Management Plan.

5. **DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:** July 9, 1989

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

September 21, 1988

TO: Principal, Teachers, Lunchroom Employees, Custodians,
Maintenance Employees and Parent Organizations

FROM: Dr. Kathy Coatney Mays

SUBJECT: EPA Rule 763.93 (G) (4) concerning non-friable asbestos
at the Jacks Creek Elementary School.

EPA Rule 763.93 (G) (4) requires the local education
agency to notify in writing of the availability of the
management plan.

The management plan is located in the Principal's Office
and may be seen at their convenience.

INFORMING BUILDING OCCUPANTS

Asbestos is a potential health hazard.

Material containing asbestos has been found in the building.

The ACM is currently in good condition and should not present a danger unless damaged or disturbed.

Avoid disturbing the ACM (e.g., do not hang plants or pictures on the ACM, do not push furniture against the ACM, do not remove ceiling tiles).

Report any evidence of disturbance or damage.

Cleaning and maintenance personnel are taking special precautions during their work to properly clean up asbestos debris and to guard against disturbing the ACM.

All ACM is inspected periodically and additional measures will be taken when needed to protect the health of building occupants.

Report any dust or debris from ACM, any change in the condition of the ACM, or any improper action of building personnel to:

Gene Cain, 901/427-1561

The ACM is found in the following locations:

- Areas 1, 2, 3, 4 - Floor tile in the halls, classrooms, library, office, two portable classrooms, two landings from the stage, cafeteria and kitchen.


Identify type and extent of ACBM to remain in the building following implementation of response actions.

SEE ATTACHED SHEET

LEA: Chester County **LEA NO.:** 120


Date: 9/30/88

Identify limits of homogeneous area and sample locations.

HOMOGENEOUS AREA ASCALE 1"=20'LEA: Chester CountyLEA NO.: 120Date: 9/30/88

Identify limits of homogeneous area and sample locations.

S

HOMOGENEOUS AREA BSCALE 1"=20' VYNL ASBESTOS FLOOR TILE


N

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.



HOMOGENEOUS AREA C


SCALE 1" = 10'

 VINYL ASBESTOS
FLOOR TILE

LEA: Chester County LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.



HOMOGENEOUS AREA D

SCALE 1" = 20'



 VINYL ASBESTOS
FLOOR TILE

LEA: Chester County LEA NO.: 120

Date: 9/30/88

Identify limits of homogeneous area and sample locations.

S



HOMOGENEOUS AREA

SCALE 1"=20'

N

LEA: Chester County LEA NO.: 120

Date: 9/30/88

In areas 1,2,3 and 4, there is assumed asphalt floor tile. This is a hard surface which releases fibers only when cut, drilled, sawed, broken or sanded. When cleaning the tile, these steps will be followed:

- I. The floor is to be cleaned using water and detergents with no chemicals.
- II. The floor is never to be sanded.
- III. All floors should be wet-mopped and all other horizontal surfaces such as the tops of light fixtures and file cabinets should be wiped with a damp cloth.
- IV. Custodians will be instructed to avoid dropping anything which may damage the tile.
- V. No dry brooms, mops or dust cloths are to be used on the tile.
- VI. A good coat of commercial grade wax is to be kept on the tile at all times.
- VII. In case of a piece of tile breaking, the following shall be observed:
 - A. The area is to be marked off.
 - B. Signs posted to prevent entry.
 - C. All HVAC units in the area closed down.
 - D. Maintenance men will come in with proper equipment after school or at night and make necessary repairs.
 - E. The wet cleaning method with HEPA filtered vacuum will be used for clean up.
 - F. All debris will be disposed of according to EPA regulations.
 - G. For major fiber release, the building will be closed down and a company accredited to remove asbestos shall be called in.
 - H. All records of the cleaning of the tile, name, date and method used, must be kept in the Principal's office.

LEA: Chester CountyLEA NO.: 120Date: 9/30/88

This plan deals with non-friable ACM and friable TSI which will become non-friable when it is repaired. Most of the TSI is isolated in the boiler rooms of Chester County High School and North Chester Elementary School.

- I. All Principals, Teachers, Lunchroom Employees, Custodians, Maintenance Employees, Students, Parents and Parent Organizations will be notified of the location of the ACM and location of the Management Plan.
(See Copy of Notification)
- II. All ACM in the floor tile must be cleaned using the wet method for cleaning and all records of the cleaning of the building must include names, dates and method used. This record will be kept in the Principal's office. The cleaning of the friable TSI will be with the wet wipe system and the HEPA Vacuum. All maintenance men performing this operation will wear an air purifying negative pressure respirator with HEPA filters and protective clothing (suits, hoods and boots). Any debris will be placed in an air tight bag and then a drum for proper disposal.
- III. Should there be a small scale fiber release, the plan for Disturbance of ACM Intended or Likely TSI will be followed. (See Attached Sheets)
- IV. All employees that wear a respirator must have a pulmonary function test or breathing test.
- V. All custodians and maintenance personnel will receive two hours of awareness training (T.H.E.-/A.C.T.-/ASHERA compliance film plus one hour of discussion of the film). Each will receive a copy of Asbestos In Buildings - Guidance for Service and Maintenance Personnel. Each maintenance man will also receive 14 additional hours of training:
 - A. Respirator for asbestos and filtering - 1 hour
 - B. HEPA vacuum cleaner for asbestos clean up - 1 hour
 - C. Maintaining asbestos covered pipes and surfaces - 2 hours
 - D. Practicing use of glove bag - 5 hours
 - E. Repairing TSI with Lag-Kap, Lag-Kloth and Lag-Kote - 5 hours
- VI. All service personnel from outside of the school must report to the Principal's office before any work can begin. At this time they will be informed of any ACM.
- VII. The ACM in each area will be inspected by a maintenance man and the date, time and condition of the ACM recorded. This will be kept in the Principal's office. The re-inspection will be in 3 years from July 9, 1989, and it will follow ASHERA 763.93 (E) (9).
- VIII. All records of activities involving ACM will be kept in the Principal's office.
 - A. Employee training
 1. Name
 2. Job Title
 3. Date training was completed

(continued)

LEA: Chester County LEA NO.: 120
Date: 9/30/88

OPERATIONS AND MAINTENANCE PROCEDURES

4. Location of training
 5. Number of hours completed
- B. Initial Cleaning
1. Name of each person performing the cleaning
 2. Date of cleaning
 3. Location
 4. Method used
- C. O and M Activities
1. Name of person performing the activity
 2. Start and completion dates
 3. Location
 4. Description of activity
- D. For Small Scale Fiber Release
1. Date and location of episode
 2. Method of repair
 3. Name of person performing the work
- E. For large scale fiber release the school will be closed and a contractor certified to do the work will be called in.
1. Name and signature of the contractor
 2. State of accreditation
 3. Accreditation number
 4. Start and completion dates
 5. Location of activity
 6. Description of activity
 7. If ACM is removed, name and location of storage or disposal sites

LEA: Chester County LEA NO.: 120
Date: 9/30/88

GEORGIA INSTITUTE OF TECHNOLOGY

This is to certify that

GENE E. CAIN

has successfully completed

Inspecting Buildings For Asbestos
Containing Materials

conducted by

GEORGIA TECH

EDUCATION EXTENSION SERVICES

Atlanta, Georgia

MARCH 21-23, 1988



President

Director, Education Extension Services
Associate Vice President for Academic Affairs

The Georgia Institute of Technology

Gene E. Cain

Has attended and satisfactorily passed an examination
covering the contents of a continuing education course entitled:


"INSPECTING BUILDINGS FOR ASBESTOS-CONTAINING MATERIALS"

Certificate Number

477

Date

March 23, 1988



Course Director

Eric Shurley

Exam Administrator

Metzler M. Malok

The Georgia Institute of Technology

Gene E. Cain

Has attended and satisfactorily passed an examination
covering the contents of a continuing education course entitled:


"MANAGING ASBESTOS IN BUILDINGS"

Certificate Number

418

Date

March 25, 1988



Course Director

Joni Hurley

Exam Administrator

Matthew Marshall

GEORGIA INSTITUTE OF TECHNOLOGY

This is to certify that

GENE E. CAIN

has successfully completed

Managing Asbestos in Buildings

conducted by

GEORGIA TECH

EDUCATION EXTENSION SERVICES



Atlanta, Georgia

MARCH 24-25, 1988



[Signature]
President

[Signature]
Director, Education Extension Services
Associate Vice President for Academic Affairs



QUALITATIVE RESPIRATOR FIT TEST

Name: GENE F. CHAIN

Social Security No.: 415-WH-5134

Respirator Type: NORTH 7760

Size M

By: R. Schmitter Date: 3/22/88

Georgia Tech Research Institute

September 21, 1988

TO: Principal, Teachers, Lunchroom Employees, Custodians,
Maintenance Employees and Parent Organizations

FROM: Dr. Kathy Coatney Mays

SUBJECT: EPA Rule 763.93 (G) (4) concerning the friable and non-
friable asbestos at Chester County High School.

EPA Rule 763.93 (G) (4) requires the local education
agency to notify in writing of the availability of the
management plan.

The management plan is located in the Principal's office
and may be seen at their convenience.

97

INFORMING BUILDING OCCUPANTS

Asbestos is a potential health hazard.

Material containing asbestos has been found in the building.

The ACM is currently in good condition and should not present a danger unless damaged or disturbed.

Avoid disturbing the ACM (e.g., do not hang plants or pictures on the ACM, do not push furniture against the ACM, do not remove ceiling tiles).

Report any evidence of disturbance or damage.

Cleaning and maintenance personnel are taking special precautions during their work to properly clean up asbestos debris and to guard against disturbing the ACM.

All ACM is inspected periodically and additional measures will be taken when needed to protect the health of building occupants.

Report any dust or debris from ACM, any change in the condition of the ACM, or any improper action of building personnel to:

Gene Cain, 901/427-1561

The ACM is found in the following locations:

- Area 1 - Lobby & Office - Asphalt floor tile.
- Area 2 - Storage room, workroom, two restrooms, Biology Room - Asphalt floor tile.
- Area 3 - Gym, corridors beside gym, Girls PE Office - Asphalt floor tile.
- Area 4 - Varsity dressing room, study hall, bookroom, classroom, Teachers Lounge - Asphalt floor tile.
- Area 5 - Home Economics, General Science, Physics Room - Asphalt floor tile.
- Area 6 - Library, eight classrooms, conference room, counselors room - Vinyl asbestos floor tile.
- Area 7 - Auditorium - Pipe wrappings in womens restroom, lobby, janitorial closet, dressing room on stage and overhead around stage.
- Area 8 - Cafeteria and Kitchen - Inlayed linoleum in cafeteria, storage room in kitchen and locker room - Vinyl asbestos floor tile.
- Area 9 - Boiler Room - Pipe wrappings and hot water tank.
- Area 10 - Agriculture Building - Corridors, bookstore and classrooms have vinyl asbestos floor tile. Pipe wrappings in boiler room, shop and shop restroom.
- Area 11 - Business Building - All classrooms have vinyl asbestos floor tile.
- Area 12 - Vocational School - Hall and storage, janitorial room, hall leading to stairs, landing on stairs, hall between shops and locker area, three office areas, janitorial closet and storage room upstairs on the right - vinyl asbestos floor tile. Pipe wrappings on the elbows of hot water tank.

EMPLOYEE TRAINING FORM

Maintenance & Custodial

Location of Training: Chester County Junior High Cafeteria

Date: Sept. 21, 1988 Period of Instruction: 3 Hrs.

Instructor (Print Name): Gene Cain - Tape (VCR)

Subject Matter Covered: T.H.E. A.C.T two hour employee A.H.E.R.A. compliance training and discussion.

ATTENDEES:

NAME (Print)	JOB TITLE
<u>Dail Ross</u>	<u>Janitor Jackson Creek</u>
<u>Alonso Roy Climer</u>	<u>Janitor East Chester</u>
<u>P.C. Burross</u>	<u>Janitor West Chester</u>
<u>J.R. Grogan</u>	<u>Janitor North Chester</u>
<u>Art J. Hysmith</u>	<u>Custodian - East</u>
<u>Shay King</u>	<u>Master</u>
<u>James J. Jones</u>	<u>Custodian - Jr. High C.H.B.</u>
<u>Usual Ross</u>	<u>Janitor Jr. High School</u>
<u>William Spencer</u>	<u>Janitor High School</u>

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person: Gene Cain

Signature: Gene Cain

LEA: Chester County LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Maintenance & Custodial

Location of Training:

Chester County Prison - High Conference

Date:

September 21, 1988

Period of Instruction:

3

Hrs.

Instructor (Print Name):

Gene Cain - Tape (VCR)

Subject Matter Covered:

T.H.E. A.C.T two hour employee A.H.E.R.A. compliance training and discussion.

ATTENDEES:

NAME (Print)

JOB TITLE

Johnny Hayes

Janitor High School

Marion C. Davis

Janitor Jr. High School

Darryl Williams

Monitor

Kathy Calney Maers

School Superintendent

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:

Gene Cain

Signature:

Gene Cain

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Location of Training: Chester County High School

Date: 9/21/1988 Period of Instruction: 2 Hrs.

Instructor (Print Name): Gene Cain

Subject Matter Covered: Maintaining asbestos covered pipes and surfaces.

ATTENDEES:

NAME (Print)	JOB TITLE
<u>James H. Miller</u>	<u>MAINT.</u>
<u>Lloyd H. Kopp</u>	<u>1111</u>

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person: Gene Cain

Signature: Gene Cain

LEA: Chester County LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Location of Training:

Chester County Courthouse

Date:

9/2/1988

Period of Instruction:

1

Hrs.

Instructor (Print Name):

Gene Cain

Subject Matter Covered: Respirators for asbestos and fitting.

ATTENDEES:

NAME (Print)

JOB TITLE

Dennis Miller

Nestor

Phyllis King

10/11

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:

Gene Cain

Signature:

Gene Cain

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Location of Training:

Chester County Courthouse

Date:

9/21/1988

Period of Instruction:

1

Hrs.

Instructor (Print Name):

Gene Cain

Subject Matter Covered:

HEPA vacuum cleaner for asbestos cleanup.

ATTENDEES:

NAME (Print)

JOB TITLE

[Signature]

[Signature]

[Signature]

[Signature]

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:

Gene Cain

Signature:

[Signature]

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Location of Training:

Chester County High School

Date:

9-24-1988

Period of Instruction:

5

Hrs.

Instructor (Print Name):

Gene Cain

Subject Matter Covered:

Repairing TSI with Lag-Kap, Lag-Kloth and Lag-Kote.

ATTENDEES:

NAME (Print)

JOB TITLE

Dwight H. H.

Meant

Shy H. Kniz

1r 11

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:

Gene Cain

Signature:

Gene Cain

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

EMPLOYEE TRAINING FORM

Location of Training:

Chester County High School

Date:

9-24-1988

Period of Instruction:

5

Hrs.

Instructor (Print Name):

Gene Cain

Subject Matter Covered:

Practice use of glove bag.

ATTENDEES:

NAME (Print)

JOB TITLE

Doug Hill

MAINT

Phyllis H. Kiny

" "

* LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:

Gene Cain

Signature:

Gene Cain

LEA:

Chester County

LEA NO.: 120

Date:

9/30/88

1. **Locations cleaned:**

All of the floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

All of the custodians of the Chester County schools.

1. Gail Ross	6. Thomas Maness
2. Glenda Kay Climer	7. Isiah Ross
3. R.C. Burross	8. William Spencer
4. J.R. Edgar	9. Johnny Hayes
5. W.T. Hepsmith	10. Marian C. Davis

Training date for all above: 9/21/88

4. **Date cleaning performed:** 6/21-24-- 7/12-15/88

5. **LEA Designated Person:** Gene Cair

Signature: 

Date: 9/30/88

LEA: Chester County LEA NO.: 120
Date: 9/30/88

1. **Locations cleaned:**

All of the floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

- | | |
|----------------------|---------------------|
| 1. Gail Ross | 6. Thomas Maness |
| 2. Glenda Kay Climer | 7. Isiah Ross |
| 3. R.C. Burross | 8. William Spencer |
| 4. J.R. Edgar | 9. Johnny Hayes |
| 5. W.T. Hepsmith | 10. Marian C. Davis |

Training date for all above: 9/21/88

4. **Date cleaning performed:** 7/18-27/885. **LEA Designated Person:** Gene Cain

Signature: *Gene Cain*

Date: 9/30/88

1. **Locations cleaned:**

All floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

- | | |
|----------------------|---------------------|
| 1. Gail Ross | 6. Thomas Maness |
| 2. Glenda Kay Climer | 7. Isiah Ross |
| 3. R.C. Burross | 8. William Spencer |
| 4. J.R. Edgar | 9. Johnny Hayes |
| 5. W.T. Hepsmith | 10. Marian C. Davis |

Training date for all above: 9/21/88

4. **Date cleaning performed:** 7/28-8/13/88

5. **LEA Designated Person:** Gene Cair

Signature: *Gene Cair*

Date: 9/30/88

LEA: Chester County LEA NO.: 120
Date: 9/30/88

1. **Locations cleaned:**

All floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

- | | |
|----------------------|---------------------|
| 1. Gail Ross | 6. Thomas Maness |
| 2. Glenda Kay Climer | 7. Isiah Ross |
| 3. R.C. Burross | 8. William Spencer |
| 4. J.R. Edgar | 9. Johnny Hayes |
| 5. W.T. Hepsmith | 10. Marian C. Davis |

Training date for all above: 9/21/88

4. **Date cleaning performed:** 6/13-17/885. **LEA Designated Person:** Gene Cain

Signature: *Gene Cain*

Date: 9/30/88

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

1. **Locations cleaned:**

All floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

- | | |
|----------------------|---------------------|
| 1. Gail Ross | 6. Thomas Maness |
| 2. Glenda Kay Climer | 7. Isiah Ross |
| 3. R.C. Burross | 8. William Spencer |
| 4. J.R. Edgar | 9. Johnny Hayes |
| 5. W.T. Hepsmith | 10. Marian C. Davis |

Training date for all above: 9/21/88

4. **Date cleaning performed:** 6/3-10/88

5. **LEA Designated Person:** Gene Cain

Signature: *Gene Cain*

Date: 9/30/88

LEA: Chester County

LEA NO.: 120

Date: 9/30/88

1. **Locations cleaned:**

All floors in the building.

2. **Cleaning methods used (pursuant to 40 CFR 763.91[a]):**

Wet method of cleaning used.

3. **Names of persons performing cleaning and training dates:**

- | | |
|----------------------|---------------------|
| 1. Gail Ross | 6. Thomas Maness |
| 2. Glenda Kay Climer | 7. Isiah Ross |
| 3. R.C. Burross | 8. William Spencer |
| 4. J.R. Edgar | 9. Johnny Hayes |
| 5. W.T. Hepsmith | 10. Marian C. Davis |

Training date for all above: 9/21/88

4. **Date cleaning performed:** 5/27-6/2/88

5. **LEA Designated Person:** Gene Cain

Signature: *Gene Cain*

Date: 9/30/88

LEA: Chester County LEA NO.: 120
Date: 9/30/88



Linda Patterson

CHESTER COUNTY BOARD OF EDUCATION

P. O. Box 327

Henderson, Tennessee 38340

Telephone 901/989-5134

KATHY COATNEY MAYS, Superintendent

M E M O

TO: Principals

FROM: Kathy Coatney Mays *Kathy Coatney Mays*

SUBJECT: Asbestos Plan

DATE: January 7, 1991

The attached copy should be put with your asbestos management plan for reference. These surveillance reports must be completed every six months.

Thank you for your attention to this matter.

KCM:cb

DWAIN SEATON, Chairman
Route 2, Beech Bluff

BILL MOORE, Vice-Chairman
1271 W. Main, Henderson

MABEL DAVIDSON
814 N. Hearn St., Henderson

DANNY SWAFFORD
Erville

JOE COX
522 Jacks Creek Circle,
Henderson

GENE HIBBITT
482 White Ave., Henderson

JOE HOLMES, JR.
Route 2, Henderson

1. Fill out every six (6) months and insert in Appendix of Management Plan

HA No.	Description of ACBM	Area Inspected	Change in Condition (if any)
1	Vinyl Asbestos Tile	All	None
2	Vinyl Asbestos Tile	All	None
3	Vinyl Asbestos Tile	All	None
4	Vinyl Asbestos Tile	All	None
6	Vinyl Asbestos Tile	All	None
7	Vinyl Asbestos Tile	All	None
8	Vinyl Asbestos Tile	All	None

2. Attach proof, sign-off sheets, notices, etc. that Paragraphs 2 and 3 on the Assurances Guide Document (TAHERA 3.0) have been properly followed through.

Date of Surveillance: 12-27-90

Surveillance Inspector's* Signature: 

Surveillance Inspector's Name: Gene Cain

AHERA Accreditation Number/Date (if applicable): 455 - 3/27/90

*Surveillance Inspector is not required to be AHERA certified. If not, indicate any relevant asbestos or AHERA training: _____

LEA Designated Person Signature: 

Dated: 12-27-90

LEA: Chester County LEA NO.: 120

Date: 12-27-90

1. Fill out every six (6) months and Insert in Appendix of Management Plan

HA No.	Description of ACBM	Area Inspected	Change in Condition (If any)
9	Vinyl Asbestos Tile	All	None

2. Attach proof, sign-off sheets, notices, etc. that Paragraphs 2 and 3 on the Assurances Guide Document (TAHERA 3.0) have been properly followed through.

Date of Surveillance: 12-27-90

Surveillance Inspector's* Signature: *Gene Cain*

Surveillance Inspector's Name: Gene Cain

AHERA Accreditation Number/Date (If applicable): 455 - 3/27/90

*Surveillance Inspector is not required to be AHERA certified. If not, Indicate any relevant asbestos or AHERA training: _____

LEA Designated Person Signature: *Gene Cain*

Dated: 12-27-90

LEA: Chester County LEA NO.: 120

Date: 12-27-90



CHESTER COUNTY BOARD OF EDUCATION

P. O. Box 327

Henderson, Tennessee 38340

Telephone 901/989-5134

Least

KATHY COATNEY MAYS, Superintendent

M E M O

TO: Principals

FROM: Kathy Coatney Mays

Kathy Coatney Mays

SUBJECT: Asbestos

DATE: October 23, 1990

Attached you will find Managing Asbestos In Place, A Building Owner's Guide to Operations and Maintenance Programs for Asbestos-Containing Materials.

Please place this in your asbestos file for future reference and for monitoring by the E.P.A.

KCM:ke

DWAIN SEATON, Chairman
Route 2, Beech Bluff

BILL MOORE, Vice-Chairman
1271 W. Main, Henderson

STEVE LONG
573 Woods Dr., Henderson

DANNY SWAFFORD
Enville

JOE COX
522 Jacks Creek Circle, Henderson

GENE HIBBETT
482 White Ave., Henderson

JOE HOLMES, JR
Route 2, Henderson



CHESTER COUNTY BOARD OF EDUCATION

P. O. Box 327
Henderson, Tennessee 38340 Telephone 901/989-5134

KATHY COATNEY MAYS, Superintendent

September 4, 1990

Mr. Bill Cobb
State of Tennessee
Department of Finance and Administration
Division of Facilities Management
Suite 206, John Sevier Building
Nashville, Tennessee

Dear Mr. Cobb:

Please find enclosed Chester County School System's progress report:

- I. Inspection and periodic surveillance has been conducted.
- II. Workers and building occupants, or their legal guardians, are informed at least once each school year of response actions and presence of asbestos.
- III. All custodial employees have had at least two hours of awareness training.
- IV. All schools were cleaned by the wet method after inspection.
- V. All maintenance employees have had sixteen hours of training.
- VI. All maintenance employees have a medical check up each year.
- VII. All pipe and boiler insulation has been restored to its original condition.
- VIII. Signs have been placed in all boiler rooms as needed.
- IX. Short term workers who may come in contact with asbestos in a school are being informed of its presence.
- X. The local representative has completed approved training courses in inspection, management planning, and supervision of abatement.
- XI. All small scale disturbances have been reported to the state.

Sincerely,

Kathy Coatney Mays, Superintendent
Chester County Schools

KCM:cb

DWAIN SEATON, Chairman
Route 2, Beech Bluff

BILL MOORE, Vice-Chairman
1271 W. Main, Henderson

STEVE LONG
573 Woods Dr., Henderson

DANNY SWAFFORD
Enville

JOE COX
522 Jacks Creek Circle, Henderson

GENE HIBBETT
482 White Ave., Henderson

JOE HOLMES, JR.
Route 2, Henderson



CHESTER COUNTY BOARD OF EDUCATION

P. O. Box 327

Henderson, Tennessee 38340

Telephone 901/989-5134

KATHY COATNEY MAYS, Superintendent

M E M O

TO: Principals *Linda Patterson*
FROM: Kathy Coatney Mays *Kathy Coatney Mays*
SUBJECT: Asbestos Inspection
DATE: January 4, 1990

I am attaching a copy of the Asbestos Periodic Surveillance Report for your school. This report is to be filed in your Asbestos Management Plan in the Appendix.

KCM:cb

DWAIN SEATON, Chairman
Route 2, Beech Bluff

BILL MOORE, Vice-Chairman
1271 W. Main, Henderson

STEVE LONG
573 Woods Dr., Henderson

DANNY SWAFFORD
Enville

JOE COX
522 Jacks Creek Circle, Henderson

GENE HIBBETT
482 White Ave., Henderson

JOE HOLMES, JR.
Route 2, Henderson

1. Fill out every six (6) months and insert in Appendix of Management Plan

HA No.	Description of ACBM	Area Inspected	Change in Condition (if any)
1	Vinyl Asbestos Tile	All	None
2	Vinyl Asbestos Tile	All	None
3	Vinyl Asbestos Tile	All	None
4	Vinyl Asbestos Tile	All	None
6	Vinyl Asbestos Tile	All	None
7	Vinyl Asbestos Tile	All	None
8	Vinyl Asbestos Tile	All	None

2. Attach proof, sign-off sheets, notices, etc. that Paragraphs 2 and 3 on the Assurances Guide Document (TAHERA 3.0) have been properly followed through.

Date of Surveillance: 12/13/89

Surveillance Inspector's* Signature: *Gene Cain*

Surveillance Inspector's Name: Gene Cain

AHERA Accreditation Number/Date (if applicable): 161 - 3/21/89

*Surveillance Inspector is not required to be AHERA certified. If not, indicate any relevant asbestos or AHERA training: _____

LEA Designated Person Signature: *Gene Cain*

Dated: 12/20/89

LEA: Chester County LEA NO.: 120

Date: 12/20/89

1. Fill out every six (6) months and insert in Appendix of Management Plan

HA No.	Description of ACBM	Area Inspected	Change in Condition (if any)
9	Vinyl Asbestos Tile	All	None

2. Attach proof, sign-off sheets, notices, etc. that Paragraphs 2 and 3 on the Assurances Guide Document (TAHERA 3.0) have been properly followed through.

Date of Surveillance: 12/13/89

Surveillance Inspector's* Signature: *Gene Cain*

Surveillance Inspector's Name: Gene Cain

AHERA Accreditation Number/Date (if applicable): 161 - 3/21/89

*Surveillance Inspector is not required to be AHERA certified. If not, indicate any relevant asbestos or AHERA training: _____

LEA Designated Person Signature: *Gene Cain*

Dated: 12/20/89

LEA: Chester County LEA NO.: 120

Date: 12/20/89

PERIODIC SURVEILLANCE REPORT**SCHOOL YEAR:** 1992-93No. #1 [X] (1st six months) Date 12-30-92

No. #2 [] (2nd six months) Date _____

SCHOOL BUILDING NAME East Chester Elementary

(Fill out every six (6) months for each school building and include in yearly Progress Report and insert in Appendix of Management Plan.)

HA No	Description of ACBM	Area Inspected	Change in Condition (if any)
1	Floor Tile	All	None
2	Floor Tile	All	None
3	Floor Tile	All	None
4	Floor Tile	All	None
6	Floor Tile	All	None
7	Floor Tile	All	None
8	Floor Tile	All	None
9	Floor Tile	All	None

Surveillance Inspector's* Signature: Gene Cain

Surveillance Inspector's Name: Gene Cain

AHERA Accreditation Number/Date (if applicable)*: 886 2/10/92

*Surveillance Inspector is not required to be AHERA certified.

LEA System Name: Chester CountyLEA NO.: 120Date: 12-30-92

SAFETY • TRAINING • ECOLOGY • DESIGN

**201 SOUTH MAIN STREET, SUITE #1
COVINGTON, TENNESSEE 38019
(901) 476-4973**

CERTIFICATE OF COMPLETION

EDDIE MILLER

has successfully completed and passed an examination for the course of

EPA/AHERA Approved Accreditation Course

Management Planner Course

December 2 - 3, 1993

Covington, Tennessee

This course has been approved by the State of IDAHO and the United States Environmental Protection Agency and is pursuant to current AHERA regulations

MP010

Certificate Number

12/03/1993

Examination Date

12/03/1994

Date of Expiration

Melanie M Wright
Classroom Instructor

Dr. B. Wright
Field Instructor

Melanie M Wright
Director of Programs

Asbestos

CERTIFICATE OF ACHIEVEMENT

Awarded to

LARRY EDDIE MILLER

In accordance with EPA TSCA Title II accreditation standards for
successful completion of the

Asbestos Management Planner Refresher Training Course

431-53-1229

Certificate Number

MAY 20, 1998

Examination Date

MAY 20, 1998

Course Date

MAY 20, 1999

Expiration Date

Angela Moore

Environmental Technologies

P. O. Box 21243

Little Rock, AR 72221

(501) 580-4284



Asbestos

CERTIFICATE OF ACHIEVEMENT

Awarded to

LARRY EDDIE MILLER

In accordance with EPA TSCA Title II accreditation standards for
successful completion of the

Asbestos Management Planner Refresher Training Course

431-53-1229

Certificate Number

May 19, 1999

Examination Date

May 19, 1999

Course Date

May 19, 2000

Expiration Date

Phyllis Moore

Environmental Technologies

P. O. Box 21243

Little Rock, AR 72221

(501) 580-4284



SAFETY • TRAINING • ECOLOGY & DESIGN, INC.
215 EAST LIBERTY AVENUE
COVINGTON, TN 38019
(901) 476-4973

CERTIFICATION OF COMPLETION

this certifies that

Eddie Miller

has attended, successfully completed and passed an examination, as required under
TSCA, Title II, for the course covering the contents of Model EPA curriculum for

Asbestos Building Inspector/Management Planner Annual Refresher Training Course

May 18th, 2000 in Memphis, Tennessee

This course has been approved by the State of Florida and the United States
Environmental Protection Agency under section 206 (a) of TSCA, 15 U.S.C. 264 (a)

BIMPR431-53-1229
Certificate Number

May 18th, 2000
Examination Date

May 18th, 2001
Expiration Date

David B. Wright
Classroom Instructor

Melanie M. Wright
Melanie M. Wright, Course Administrator





M·E·T·A

Mayhew Environmental Training Associates

I N C O R P O R A T E D

Certificate # 7ME01187306MPR004

This is to certify that

Eddie Miller

has on 01/18/01, in MEMPHIS, TN

completed the requirements for asbestos accreditation under Section 206 of TSCA, Title II, 15 U.S.C. 2646

AHERA Asbestos Management Planner Recertification Course

as approved by the U.S.E.P.A. under 40 C.F.R. 763 (AHERA)

*on 01/18/01 - 01/18/01 and passed the associated examination on 01/18/01
with a score of 70% or better*

CM =



Instructor

R. Bull
President

Soc. Sec #: 431-53-1229
Accreditation Expires: 01/18/02

META - P.O. Box 786 - Lawrence KS 66044 - 800-444-6382

Asbestos

CERTIFICATE OF ACHIEVEMENT

Awarded to

EDDIE MILLER

In accordance with EPA TSCA Title II accreditation standards for
successful completion of the

Asbestos Management Planner Refresher Training Course

431-53-1229

Certificate Number

January 23, 2002


Examination Date

January 23, 2002

Course Date

January 23, 2003

Expiration Date



Environmental Technologies

P.O. Box 21243

Little Rock, AR 72221

(501) 425-9585



Asbestos
REFRESHER

Asbestos

CERTIFICATE OF ACHIEVEMENT

Awarded to

EDDIE MILLER

In accordance with EPA TSCA Title II accreditation standards for
successful completion of the

Asbestos Management Planner Refresher Training Course

431-53-1229

Certificate Number

January 23, 2003

Examination Date

January 23, 2003

Course Date

January 23, 2004

Expiration Date




Environmental Technologies

P. O. Box 21243

Little Rock, AR 72221

(501) 425-9585



Asbestos
REFRESHER

AHERA YEARLY PROGRESS REPORT PACKAGE



DEPARTMENT OF FINANCE AND ADMINISTRATION
CAPITAL PROJECTS MANAGEMENT
ENVIRONMENTAL PROGRAMS

**ANNUAL PROGRESS REPORT
INSTRUCTION GUIDE**

This packet contains the forms necessary to complete the AHERA Annual Progress Report. This packet should be completed every year and SUBMITTED BY JULY 9 to:

STATE OF TENNESSEE
Capital Projects Management
Environmental Programs Section
Suite 500, 511 Union Street
Nashville, TN 37243-0300

Attention: George G. Brummett, Jr.

This packet was developed to help Local Education Agencies (LEAs) to meet the requirements of record keeping as outlined in AHERA. THE LEA Designated Person may complete this packet. AN AHERA accredited inspector or Management Planner does not have to complete this packet.

AT A MINIMUM, completed copies of the following forms should be submitted to the State, the original documents must be kept with your Management Plan.

1. Transmittal Sheet/AHERA Submittals (TAHERA 1.0)
2. Checklist for Yearly Progress Report (TAHERA 1.1)
3. Assurances Form (TAHERA 3.0)
4. Dated Annual Written Notification
5. Periodic Surveillance Report Form (TAHERA 9.0)
6. Annual Progress Report (TAHERA 15.0)

Additional forms may also need to be submitted. Please review the Checklist For Yearly Progress Reports (TAHERA 1.1) in order to determine the need for additional forms. The list below indicates the additional forms that have been included for your use if needed.

1. School Building List (TAHERA 5.0)
2. School Information/Certification Form (TAHERA 6.1A)
3. Abatement Action (TAHERA 10.0)
4. Employee Training Form (TAHERA 11.0)
5. Operations and Maintenance Activity (TAHERA 12.0)
6. Cleaning Record (TAHERA 13.0)
7. Fiber Release Episode (TAHERA 14.0)

TRANSMITTAL SHEET/AHERA SUBMITTALS**LEA System Name:** Chester County **LEA #** 120**Address:** P O Box 327**County:** Henderson TN 38340**LEA Designated Person:** Gene Cain **Telephone:** 901-424-6428**Date:** May 24, 1995

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN 'X' IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/ DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT
		REINSPECTION
		Other (please explain)

CHECKLIST FOR YEARLY PROGRESS REPORTS**SCHOOL YEAR ENDING** June 30, 1995**Page 1 of 2**

A Progress Report must be completed and incorporated into your Management Plan yearly to assure compliance with the mandates of AHERA. This checklist and attached forms will assist you in meeting these record keeping requirements.

Attached	Not Applicable	Will be sent by Management Planner	
X			1. Transmittal Sheet/AHERA Submittals (TAHERA 1.0)
X			2. Checklist for Yearly Progress Reports (TAHERA 1.1)
X			3. Assurances (TAHERA 3.0)
X			4. Periodic Surveillance Report (TAHERA 9.0)
X			5. Annual Progress Report (TAHERA 15.0)
X			6. Notice to the parents, teachers, and employees stating where the Management Plan is located.

ADDITIONAL FORMS THAT MAY BE REQUIRED TO BE FILED WITH THE STATE
(Please indicate whether any of these forms are necessary for your LEA).

Attached	Not Applicable	Will be sent by Management Planner	
	X		1. Revised School Building List (TAHERA 5.0) This form must include all new school buildings or additions.
	X		2. School Information/Certification Form (TAHERA 6.1A) This form must be completed for all buildings and additions completed during the last year. Attach letter(s) from Architect, Engineer, or accredited Inspector if: a. If an existing building is acquired after 10/12/88, and is intended to be used as a new school or as a part of an existing school, an AHERA Inspection Management Plan shall be conducted PRIOE to the use of the building as a school building. PLEASE NOTE THAT THE MANAGEMENT PLAN MUST BE SUBMITTED TO THIS OFFICE PRIOR TO USE OF THE BUILDING AS A SCHOOL FACILITY.

CHECKLIST FOR YEARLY PROGRESS REPORTS

Page 2 of 2

Attached	Not Applicable	Will be sent by Management Planner	
	X		b. If a new building is constructed after 10/12/88, and is intended to be used as a school, an AHERA inspection Management Plan shall be conducted <u>PRIOR</u> to the use of the building as a school building. The inspection and assessment of the building materials may be waived if an Architect, Project Engineer responsible for the construction of the building, or an accredited inspector signs a statement that (1) no ACBM was specified as a building material in any construction document for the building or (2) to the best of his/her knowledge, no ACBM was used as a building material in the building. If such a statement is obtained, the LEA shall submit a copy of the signed statement to EPA Regional Office and shall include the statement in the Management Plan for the school.
	X		8. Abatement Action (TAHERA 10.0) This form must be completed for any removal, enclosure, encapsulation or repair greater than 8 square or linear feet. Please attach a copy of the air monitoring report.
X			4. Employee Training Form (TAHERA 11.0) This form must be completed for any new custodial and maintenance employees. Training must be completed within sixty days (60) days of commencement of employment.
	X		5. Operations and Maintenance Activity (TAHERA 12.0) This form must be completed for any removal, enclosure, encapsulation or repair less than 8 square or linear feet.
	X		6. Cleaning Record (TAHERA 13.0) This form must be completed for any initial or additional cleaning as recommended by your Management Planner. Initial cleaning must be conducted for all schools containing friable asbestos.
	X		7. Fiber Release Episode Form (TAHERA 14.0) This form must be completed for the falling or dislodging of asbestos-containing materials in any quantity.

Chester County

LEA System Name: _____

LEA NO: 120

DATE: May 24, 1995

ASSURANCES

SCHOOL YEAR ENDING

06-30-95

This AHERA Management Plan was developed and has been submitted pursuant to the Asbestos Hazard Emergency Response Act of 1986, Public Law 99-519; and the United States Environmental Protection Agency Rule: Asbestos Containing Material in Schools, 40 CFR Part 763, Subpart E.; and the undersigned does hereby certify that the Local Education Agency (LEA) indicated below has and will ensure the following:

1. The activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Part 763 and other State rules and requirements.
2. All custodial and maintenance employees are properly trained as required in Part 763 and all other applicable Federal and State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule or applicable State regulations).
3. All workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities, that are planned or in progress.
4. All short term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of asbestos-containing materials (ACM).
5. All warning labels are posted in accordance with Section 763.95.
6. All management plans are available for inspection and notification of such availability has been provided as specified in the AHERA regulations under Paragraph 763.93(g).
7. The undersigned person designated by the LEA pursuant to Paragraph 763.84(g)(1) has received adequate training as stipulated in Paragraph 763.84(g)(2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship between the Management Planner and other accredited persons performing AHERA activities.

LEA DESIGNATED PERSON'S NAME (please print): Gene CainLEA DESIGNATED PERSON'S SIGNATURE: 

Dr. Kathy Coatney Mays

SUPERINTENDENT'S NAME (please print):

SUPERINTENDENT'S SIGNATURE: LEA System Name: Chester CountyLEA NO: 120DATE: May 24, 1995

PERIODIC SURVEILLANCE REPORT

SCHOOL NAME: Jack's Creek Elementary


BUILDING NAME: Main Building

SCHOOL YEAR: 94 - 95

(Fill this form out every six (6) months for each school building; attach to your Yearly Progress Report and submit a copy to the State. The original of this document must be kept with your Management Plan.)

HA#	DESCRIPTION OF ACBM	AREA INSPECTED	1st six months	2nd six months
			DATE <u>12-07-94</u>	DATE <u>05-23-95</u>
1	Floor Tile	ALL	Good	N/C
2	Floor Tile	ALL	Good	N/C
3	Floor Tile	ALL	Good	N/C
4	Floor Tile	ALL	Good	N/C
	Ceiling Tile	ALL	Good	N/C

Surveillance Inspector's Name (please print): Gene Cain

Surveillance Inspector's Signature: 
(Surveillance Inspector is not required to be AHERA certified.)

AHERA Accreditation Number/Date (if applicable): Georgia Tech - 1839 - 2/7/95

LEA System Name: Chester County

LEA NO: 120

DATE: May 24, 1995

ANNUAL PROGRESS REPORT

SCHOOL NAME: Jack's Creek Elementary

BUILDING NAME: Main

SCHOOL YEAR: 94 - 95

SUMMARY OF RESPONSE ACTIONS:

LEGEND

- A Institute Preventative Measures
- B O & M
- C Repair
- D Encapsulate
- E Enclose
- F Remove
- G Isolate
- H Other (Explain)

Material Description	1	2	3	4	Ceiling Tile										
NA Number	1	2	3	4											

LEA SELECTED RESPONSE ACTION (See Legend)

CHECK ONE

A	X	X	X	X	X										
B	X	X	X	X	X										
C															
D															
E															
F															
G															
H															

RESPONSE ACTION COMPLETED?

CHECK ONE

YES															
NO	X	X	X	X	X										

RESPONSE ACTION IN PROGRESS?

CHECK ONE

YES	X	X	X	X	X										
NO															

MANAGEMENT PLAN SCHEDULE COMPARISON

CHECK ONE

On Schedule	X	X	X	X	X										
Ahead Schedule															
Behind Schedule															

INSPECTOR'S NAME (please print): Gene Cain

INSPECTOR'S SIGNATURE: 

LEA System Name: Chester County

LEA NO: 120

DATE: May 24, 1995



CHESTER COUNTY BOARD OF EDUCATION

P.O. Box 327 • Henderson, Tennessee 38340 • Telephone 901 989-5134
KATHY COATNEY MAYS, Superintendent

August 10, 1994

DWAIN SEATON, Chairman
Route 2 • Beech Bluff

DANNY SWAFFORD, Vice Chairman
Enville

MABEL DAVIDSON
814 Hearn St. - Henderson

DWIGHT BINGHAM
P.O. Box 251 - Henderson

JIM CHANDLER
155 Second St. - Henderson

BOB MOORE
2435 Old Friendship Rd. - Finger

GLENN NAYLOR
3420 Old Finger Rd. - Finger

Tennessee Department of Finance & Administration
Capital Projects Management Division
Suite 500, Nashville City Center
511 Union Street
Nashville, Tennessee 37245-0300

Dear Sir:

This is to verify that the Chester County School System has duplicated the attached asbestos letters and disseminated to all students, parents, personnel, and Parent-Teacher Organization officers. These were distributed on August 10, 1994.

Sincerely,

Kathy Coatney Mays, Superintendent
Chester County Schools

KCM:cb

Attachments

TO: Principal, Teachers, Lunchroom Employees, Custodians,
Maintenance Employees and Parent Organizations

FROM: Dr. Kathy Coatney Mays

SUBJECT: EPA Rule 763.93 (G) (4) concerning non-friable asbestos
at the Jacks Creek Elementary School.

EPA Rule 763.93 (G) (4) requires the local education
agency to notify in writing of the availability of the
management plan.

The management plan is located in the Principal's Office
and may be seen at their convenience.

OCCUPANT INFORMATION RECORD

DOCUMENT NUMBER: _____

DATE: _____

RECEIPT ACKNOWLEDGING THAT I HAVE BEEN INFORMED OF
THE PRESENCE OF ASBESTO-CONTAINING BUILDING
MATERIALS IN:

Building Number and Name

120

0025

Jacks Creek Elementary School

Building Location

General Delivery

Jacks Creek, TN 38347

I FURTHER ACKNOWLEDGE THAT THE INFORMATION
PROVIDED TO ME INCLUDED THE FOLLOWING:

- 1) THE LOCATIONS OF ASBESTO-CONTAINING MATERIALS TO WHICH I MIGHT HAVE ACCESS IN THE NORMAL COURSE OF MY PRESENCE IN THE BUILDING.
- 2) THE HAZARDS TO HEALTH PRESENTED BY ASBESTOS.
- 3) APPROPRIATE BEHAVIOR IN THE PRESENCE OF ASBESTO-CONTAINING MATERIALS WHICH WILL PREVENT OR REDUCE THE POTENTIAL HAZARD.
- 4) NOTIFICATION PROCEDURES WHICH I MUST FOLLOW IN THE EVENT I OBSERVE A POSSIBLE CHANGE IN THE CONDITION OF ANY OF THE ASBESTOS-CONTAINING MATERIALS.
- 5) SAFETY PROCEDURES WHICH I AM TO FOLLOW IN THE EVENT OF AN EMERGENCY WHICH MIGHT INVOLVE THE ASBESTOS-CONTAINING MATERIALS.

MY REASON FOR BEING IN THE BUILDING IS:

My Signature In acknowledgment of the above.

Please Print Your Name

Employer Name, Address and Phone Number

INFORMING BUILDING OCCUPANTS

Asbestos is a potential health hazard.

Material containing asbestos has been found in the building.

The ACM is currently in good condition and should not present a danger unless damaged or disturbed.

Avoid disturbing the ACM (e.g., do not hang plants or pictures on the ACM, do not push furniture against the ACM, do not remove ceiling tiles).

Report any evidence of disturbance or damage.

Cleaning and maintenance personnel are taking special precautions during their work to properly clean up asbestos debris and to guard against disturbing the ACM.

All ACM is inspected periodically and additional measures will be taken when needed to protect the health of building occupants.

Report any dust or debris from ACM, any change in the condition of the ACM, or any improper action of building personnel to:

Gene Cain, 901/427-1561

The ACM is found in the following locations:

Areas A, B, C, D - Floor tile in the halls, classrooms, library, office, two portable classrooms, two landings from the stage, cafeteria and kitchen.

EMPLOYEE TRAINING FORM**SCHOOL YEAR:** 94 - 95

=====

USE THIS FORM TO DOCUMENT TRAINING OF CUSTODIAL AND MAINTENANCE EMPLOYEES. PROVIDE ONE FORM FOR EVERY SCHOOL.

Asbestos awareness

Subject Matter Covered:**Date:** May 8, 1995 **Period of Instruction:** _____ **Hrs.** _____**Instructor (Print Name):** Kathy Coatney Mays **Agency:** _____**ATTENDEES:****NAME (Print)****JOB TITLE**

See Attached List

*LEA Designated Person certifies that the person indicated attended the above described AHERA Compliance Training Program.

LEA Designated Person:**Signature:** **LEA System Name:** Chester County**LEA NO.:** 120**Date:** May 24, 1995

TAHERA11.0(3/91)

Asbestos - Awareness Training

I have this date, December 14, 1994 participated in an awareness training session for asbestos awareness.

NAME

SCHOOL

- | | | |
|-----|-------------------|--------------|
| 1. | Tommy Kipping | CHS |
| 2. | Bracton L. Lacey | |
| 3. | P. C. Burrass | West County |
| 4. | M. Davis | CHS |
| 5. | Kenneth Schindler | CHS |
| 6. | Patricia Strain | North |
| 7. | Ken Stue | Voc |
| 8. | Shelley Smith | |
| 9. | Johnny Hayes | C. C. H. S. |
| 10. | William Spencer | CHS |
| 11. | William Hymith | East |
| 12. | Dianne Hymith | East |
| 13. | Gail Ross | J. C. School |
| 14. | | |
| 15. | | |
| 16. | | |
| 17. | | |
| 18. | | |
| 19. | | |
| 20. | | |
| 21. | | |
| 22. | | |
| 23. | | |
| 24. | | |
| 25. | | |

May 12, 1994

This is to certify that I participated in safety training with Michael Young on May 12, 1994. This included safety procedures, wearing back braces, right-to-know, blood borne pathogens, asbestos dangers, etc. Michael covered proper lifting procedures also

1. Kathy Coatsmy (Map)
2. Willow Spence
3. Johnny Hayes
4. Gail Ross
5. Terry Johnson
6. P.C. Burrows
7. Patti Strong
8. Dianne Hyssmith
9. Wilbur Hyssmith
10. Kuni E. Schindler
11. Marion C. Davis
- 12.

School
Superintendent Office
C.C. H.S.
High School
Jack Creek

West Chester
North Chester
East Chester
East
CCJHS
CCJHS

Joint Meeting
May 8, 1995

The following participated in training
on May 8, 1995 at Chester County General
High School in handwashing procedures,
Hepatitis B and A guidelines to follow,
right-to-know, and asbestos procedures:

1. Kathy Coatsworth May
2. Wilbur W. Hysmith
3. Dianne Hysmith
4. Pattie S. Strang
5. Gail Ross
6. Johnny Hayes
7. Wilton Spencer
8. Tommy Riggins
9. Marion C. Davis
10. Dr. C. Burross
- 11.

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 8/14/98

LEA SYSTEM NAME: Chester County Board of Education **LEA #:** 120

ADDRESS: Courthouse

Henderson, TN 38340

DESIGNATED PERSON: John H. Shelton **PHONE:** (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

LEA NAME: Chester County Schools LEA #: 120
 SCHOOL BUILDING NAME: Jack's Creek Elementary BUILDING #: Main Building
 DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7-09-89 INSPECTION DATE: 8-03-98



CHECK ONE

TSI
 SURFACING
 MISCELLANEOUS
 * CHECK ONE
 ASSUMED ACBM
 CONFIRMED ACBM
 NON-ACBM
 CHECK ONE
 NON-FRIABLE
 FRIABLE
 EXPOSURE CONSIDERATION
 1 TO 5 (5 WORST)
 DETERIORATION
 PHYSICAL DAMAGE
 WATER DAMAGE
 ACTIVITY / VIBRATION
 EXPOSURE
 ACCESSIBILITY
 LENGTH OF EXPOSURE
 (CHECK ONE)
 1 HOUR / WEEK
 5 HOUR / WEEK
 10 HOUR / WEEK
 20 HOUR / WEEK
 40 HOUR / WEEK
 EXPOSURE POPULATION
 (CHECK ALL APPLICABLE)
 MAINTENANCE
 CUSTODIAL
 FACULTY / STAFF
 PUBLIC
 ASSESSMENT
 (MARK FROM 1 TO 7)
 * RESPONSE ACTIONS
 (MARK FROM A TO H)

HA NUMBER 1	HA NUMBER 2	HA NUMBER 3	HA NUMBER 4
CURRENT QUANTITY 6401 sq. ft.	CURRENT QUANTITY 42 sq. ft.	CURRENT QUANTITY 959 sq. ft.	CURRENT QUANTITY 1512 sq. ft.
MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION Floor Tile
LAST 3 YEAR	LAST 3 YEAR	LAST 3 YEAR	LAST 3 YEAR
CURRENT	CURRENT	CURRENT	CURRENT
X	X	X	X
X	X	X	X
X	X	X	X
X	X	X	X
1	1	1	1
1	1	1	1
1	1	1	1
3	3	3	3
5	5	5	5
5	5	5	5
X	X	X	X
X	X	X	X
X	X	X	X
X	X	X	X
5	5	5	5
5	5	5	5
A-B	A-B	A-B	A-B

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

- * If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
- ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Eddie Miller
 INSPECTOR (Typed name)

 Eddie Miller
 MANAGEMENT PLANNER

SIGNATURE

 SIGNATURE

431531229 / TN
 ACCREDITATION #/STATE

 431531229 / TN
 ACCREDITATION #/STATE

LEA NAME: Chester County SchoolsLEA #: 120SCHOOL BUILDING NAME: Jack's Creek ElementaryBUILDING #: PortableDATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7-09-89INSPECTION DATE: 8-03-98

CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY / VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR / WEEK

5 HOUR / WEEK

10 HOUR / WEEK

20 HOUR / WEEK

40 HOUR / WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY / STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

RESPONSE ACTIONS

(MARK FROM A TO H)

HA NUMBER
Through OutCURRENT QUANTITY
15,000 sq.ft

MATERIAL DESCRIPTION

Ceiling TileLAST
3 YEAR

CURRENT

X XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX XX X

HA NUMBER

CURRENT QUANTITY

MATERIAL DESCRIPTION

LAST
3 YEAR

CURRENT

HA NUMBER

CURRENT QUANTITY

MATERIAL DESCRIPTION

LAST
3 YEAR

CURRENT

HA NUMBER

CURRENT QUANTITY

MATERIAL DESCRIPTION

LAST
3 YEAR

CURRENT

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM.
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

- * If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
- ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Eddie Miller
INSPECTOR (Typed name)

SIGNATURE

Eddie Miller
MANAGEMENT PLANNER

SIGNATURE

431531229 / TN
ACCREDITATION #/STATE431531229 / TN
ACCREDITATION #/STATE

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 791

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN


BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

HA #	DESCRIPTION OF ACBM	AREA INSPECTED	1ST SIX MONTHS	2ND SIX MONTHS	DATE REMOVED
			DATE FALL: 10-6-97	DATE SPRING 4-03-98	
1	FLOOR TILE	ALL	GOOD	N/C	
2	FLOOR TILE	ALL	GOOD	N/C	
3	FLOOR TILE	ALL	GOOD	N/C	
4	FLOOR TILE	ALL	GOOD	N/C	
	CEILING TILE	ALL	GOOD	N/C	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): EDDIE MILLER

SURVEILLANCE INSPECTOR'S SIGNATURE: 

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): ENVIRONMENTAL TECHNOLOGIES #431531229 - 5/20/98-99

ANNUAL PROGRESS REPORT

SCHOOL NAME: Jack's Creek Elementary

BUILDING NAME: Main

SCHOOL YEAR: 97-98

SUMMARY OF RESPONSE ACTIONS:

LEGEND

- A Institute Preventative Measures
- B O & M
- C Repair
- D Encapsulate
- E Enclose
- F Remove
- G Isolate
- H Other (Explain)

Material Description	1	2	3	4	Ceiling Tile									
HA Number	1	2	3	4										

LEA SELECTED RESPONSE ACTION (See Legend)

CHECK ONE

A	X	X	X	X	X									
B	X	X	X	X	X									
C														
D														
E														
F														
G														
H														

RESPONSE ACTION COMPLETED?

CHECK ONE

YES														
NO	X	X	X	X	X									

RESPONSE ACTION IN PROGRESS?

CHECK ONE

YES	X	X	X	X	X									
NO														

MANAGEMENT PLAN SCHEDULE COMPARISON

CHECK ONE

On Schedule	X	X	X	X	X									
Ahead Schedule														
Behind Schedule														

INSPECTOR'S NAME (please print): Eddie Miller

INSPECTOR'S SIGNATURE: 

LEA System Name: Chester County

LEA NO: 120

DATE: 8-3-98

1999
Yearly Progress Report

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS:

AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE:

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

2000
Yearly Progress Report

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE: *[Signature]*

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM

DATE: September 25, 2003

LEA SYSTEM NAME: Chester County Board of Education

LEA #: 120

ADDRESS:

Henderson, TN 38340

DESIGNATED PERSON: John Pipkin

PHONE: (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT - 1999
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE:

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: September 25, 2003

LEA SYSTEM NAME: Chester County Board of Education

LEA #: 120

ADDRESS:

Henderson, TN 38340

DESIGNATED PERSON: John Pipkin

PHONE: (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT - 2000
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

				1ST SIX MONTHS		2ND SIX MONTHS	
				DATE FALL:	9-22-99	DATE SPRING:	3-31-00
HA #	DESCRIPTION OF ACB	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*		DATE REMOVED	
1	FLOOR TILE	ALL	GOOD	N/C			
2	FLOOR TILE	ALL	GOOD	N/C			
3	FLOOR TILE	ALL	GOOD	N/C			
4	FLOOR TILE	ALL	GOOD	N/C			
	CEILING TILE	ALL	GOOD	N/C			

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE: 

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM

DATE: September 25, 2003

LEA SYSTEM NAME: Chester County Board of Education

LEA #: 120

ADDRESS:

Henderson, TN 38340

DESIGNATED PERSON: John Pipkin

PHONE: (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION - 2001
		OTHER (Please Explain)

2002
Yearly Progress Report

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE:

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM

DATE: September 25, 2003

LEA SYSTEM NAME: Chester County Board of Education

LEA #: 120

ADDRESS:

Henderson, TN 38340

DESIGNATED PERSON: John Pipkin

PHONE: (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT - 2002
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE:

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

THREE YEAR REINSPECTION

LEA NAME:	CHESTER COUNTY SCHOOLS	LEA #:	120
SCHOOL BLDG. NAME:	JACK'S CREEK ELEMENTARY	BUILDING #	MAIN BUILDING
DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:	7/9/1989	INSPECTION DATE:	8/13/2003



	HA 01	HA 02	HA 03	HA 04
CURRENT QUANTITY	6401	42	959	1512
MATERIAL DESCRIPTION	FLOOR TILE	FLOOR TILE	FLOOR TILE	FLOOR TILE
LAST 3 YEAR	M	M	M	M
CURRENT	M	M	M	M
MATERIAL TYPE	M	M	M	M

Check One

ASSUMED ACBM	X	X	X	X	X	X	X
CONFIRMED ACBM							
NON-ACBM							

Check One

NON-FRIABLE	X	X	X	X	X	X	X
FRIABLE							

Exposure Consideration

DETERIORATION	1	1	1	1	1	1	1
PHYS. DAMAGE	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1
ACTIVITY / VIBR.	3	3	3	3	3	3	3
EXPOSURE	5	5	5	5	5	5	5
ACCESSIBILITY	5	5	5	5	5	5	5

Length of Exposure

1 HOUR / WEEK							
5 HOUR / WEEK							
10 HOUR / WEEK							
20 HOUR / WEEK							
40 HOUR / WEEK	X	X	X	X	X	X	X

Exposure Population

MAINTENANCE	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X
FACULTY / STAFF	X	X	X	X	X	X	X
PUBLIC	X	X	X	X	X	X	X

Assessment

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

** Response Actions

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

Assessment Legend

1. Damaged/ significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACM

Response Actions Legend

- | | |
|------------------------------------|--------------|
| A. Institute Preventative Measures | E. Enclosure |
| B. O and M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

Notes

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0.
 **If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

CHESTER ERVIN

INSPECTOR (Typed Name)

SIGNATURE

EDDIE MILLER

MANAGEMENT PLANNER

SIGNATURE

ACCREDITATION # /STATE

431531229 / TN

ACCREDITATION # /STATE

TAHERA 16.0 (12/93)

THREE YEAR REINSPECTION

LEA NAME: **CHESTER COUNTY SCHOOLS** LEA #: **120**
 SCHOOL BLDG. NAME: **JACK'S CREEK ELEMENTARY** BUILDING #: **PORTABLES**
 DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: **7/9/89** INSPECTION DATE: **8/13/2003**



THROUGHOUT

CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
15,000			
MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
2 X 4 CEILING TILE			
LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
M	M		
MATERIAL TYPE	MATERIAL TYPE	MATERIAL TYPE	MATERIAL TYPE

Check One

ASSUMED ACBM	X	X				
CONFIRMED ACBM						
NON-ACBM						

Check One

NON-FRIABLE	X	X				
FRIABLE						

Exposure Consideration

DETERIORATION	1	1				
PHYS. DAMAGE	1	1				
WATER DAMAGE	1	1				
ACTIVITY / VIBR.	3	3				
EXPOSURE	3	3				
ACCESSIBILITY	5	5				

Length of Exposure

1 HOUR / WEEK						
5 HOUR / WEEK						
10 HOUR / WEEK						
20 HOUR / WEEK						
40 HOUR / WEEK	X	X				

Exposure Population

MAINTENANCE	X	X				
CUSTODIAL	X	X				
FACULTY / STAFF	X	X				
PUBLIC	X	X				

Assessment

5	5					
** Response Actions	A-B	B				

Assessment Legend

1. Damaged/ significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACM

Response Actions Legend

- | | |
|------------------------------------|--------------|
| A. Institute Preventative Measures | E. Enclosure |
| B. O and M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

Notes

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0.
 **If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

CHESTER ERVIN

INSPECTOR (Typed Name)

EDDIE MILLER

MANAGEMENT PLANNER

SIGNATURE

SIGNATURE

ACCREDITATION # /STATE

AR 431531229

ACCREDITATION # /STATE

TAHERA 16.0 (12/93)

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: September 25, 2003

LEA SYSTEM NAME: Chester County Board of Education

LEA #: 120

ADDRESS:

Henderson, TN 38340

DESIGNATED PERSON: John Pipkin

PHONE: (901) 664-2561

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX.**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT - 2003
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE: [Signature]

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

2003
Yearly Progress Report

Ashley -

Resolutions Inc.
(Asbestos Inspection)

May 30 ?

615-865-8813

615-868-4140 FAX

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY SCHOOLS

LEA #: 120

SCHOOL NAME: JACK'S CREEK ELEMENTARY

SCHOOL #: MAIN

BUILDING NAME: JACK'S CREEK ELEMENTARY

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column, fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): CHESTER ERVIN

SURVEILLANCE INSPECTOR'S SIGNATURE: Yusef W. E.

(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): SEE TAHERA FORM 2.0 ATTACHMENTS

TAHERA 9.0 (12/93)

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: July 2007

LEA SYSTEM NAME: Chester County Board of Education **LEA#:** 120

ADDRESS: P.O. Box 327
Henderson, TN 38340

DESIGNATED PERSON: John Pipkin **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 6/6/07



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

ASSESSMENT (MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
1	2	3	4
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	Floor Tile	Floor Tile	Floor Tile

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X
---	---	---	---	---	---	---	---

1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1

X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

- *If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Jim Brooks
INSPECTOR (Typed Name)

Ashlie Rawlings
MANAGEMENT PLANNER

Jim Brooks
SIGNATURE
Ashlie Rawlings
SIGNATURE

7ME02050701A100007/TN
ACCREDITATION #/STATE

7ME02160701AMPR004/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 6/6/07



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS

(MARK FROM A TO H)

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
2x4 Ceiling Tile			

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X						

X	X						

X	X						

1	1						
1	1						
1	1						
1	1						
1	1						
1	1						

X	X						

X	X						
X	X						

7	7						
---	---	--	--	--	--	--	--

B	B						
---	---	--	--	--	--	--	--

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Jim Brooks
INSPECTOR (Typed Name)

Ashlie Rawlings
MANAGEMENT PLANNER

SIGNATURE

SIGNATURE

7ME02050701A100007/TN
ACCREDITATION #/STATE

7ME02160701AMPR004/TN
ACCREDITATION #/STATE



M·E·T·A

Mayhew Environmental Training Associates

INCORPORATED

Certificate # 7ME02050701A100007

This is to certify that

Jim Brooks


*has on 02/07/2007, in Nashville, TN
completed the requirements for asbestos accreditation under Section 206 of TSCA Title II, 15 U.S.C. 2646*

AHERA Asbestos Inspector Training

*as approved by the U.S.E.P.A. under 40 C.F.R. 763 (AHERA)
on 02/05/2007 - 02/07/2007 and passed the associated examination on 02/07/2007
with a score of 70% or better
CM = 3.00 Pts.*




Accreditation Expires: 2/7/08


Instructor
Ronald Francis


President
Thomas Bradford Mayhew

META - P.O. Box 786 - Lawrence KS 66044 - 800-444-6382



M·E·T·A

Mayhew Environmental Training Associates

I N C O R P O R A T E D

Certificate # 7ME02160701AMPR004


This is to certify that

L Ashlie Rawlings

*has on 02/16/2007, in Nashville, TN
completed the requirements for asbestos accreditation under Section 206 of TSCA Title II, 15 U.S.C. 2646*


AHERA Asbestos Management Planner Refresher Course

*as approved by the U.S.E.P.A. under 40 C.F.R. 763 (AHERA)
on 02/16/2007 - 02/16/2007 and passed the associated examination on 02/16/2007
with a score of 70% or better
CM = 0.50 Pts.*




Accreditation Expires: 2/16/08

META - P.O. Box 786 - Lawrence KS 66044 - 800-444-6382


Instructor
Ronald Francis


President
Thomas Bradford Mayhew



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

TERRY MOODY

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

MIKE TIGNOR

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.


Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

DANA MEEKS

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

KIM ROBBINS

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING


Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

DARLENE HESTER

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING


Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

LAURA GAUGER

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.


Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

BRENDA PICKETT

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340


Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

DEVEN HEARN

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.

Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

ANGIE PARRISH

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING


Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010




Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

TODD DAVIS

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

DEMETRIUS LOCKETT

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.

Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

MELISSA MURLEY

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

TERESA CONNER

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

YVONNE CROSS

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

WILLIE TROHER

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

JANE SMITH

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010





Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

TERESA WILLIS

Has successfully completed the course entitled


CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010




Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

KEN WEST

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING


Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: July 28, 2009

Expiration Date: July 28, 2010



Ron Francis – Training Manager



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

Identification

Number: OSHAC4AA100179

PERRY FRYE

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340


Training Date: January 20, 2010

Expiration Date: January 20, 2011

Ron Francis – Training Manager



Stephanie Petty - Instructor



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

Identification

Number: OSHAC4AA100178

JAMES CARSON

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340


Training Date: January 20, 2010

Expiration Date: January 20, 2011

Ron Francis – Training Manager



Stephanie Petty - Instructor



RESOLUTION, INCORPORATED
1101-A DARBYTOWN DRIVE
NASHVILLE, TN. 37207
(615) 865-8813

Certifies That

Identification

Number: OSHAC4AA100177

CLARENCE PUSSEY

Has successfully completed the course entitled

CLASS IV ASBESTOS 2 HOUR AWARENESS TRAINING

Conducted At: 930 East Main St.
Henderson, TN 38340

Training Date: January 20, 2010

Expiration Date: January 20, 2011



Ron Francis - Training Manager





Stephanie Petty - Instructor

Certificate of Completion

Chester County School System

Vernie Reeves

has completed

Asbestos Awareness (K-12 Full 2 Hour)

a training program requiring 2 hours

on

Monday, November 11, 2013

Training Coordinator's Signature

Employees Initials: _____

westk@tennk12.net 61029q68-2p9r



Certificate of Completion

Chester County School System

Carissa Miller

has completed

Asbestos Awareness (K-12 Full 2 Hour)

a training program requiring 2 hours


on

Monday, November 11, 2013

Training Coordinator's Signature

Employees Initials: _____

westk@tennk12.net 61029468-2p9r



Certificate of Completion

Chester County School System

Marilyn Amos

has completed

Asbestos Awareness (K-12 Full 2 Hour)

a training program requiring 2 hours

on

Monday, November 11, 2013


Training Coordinator's Signature

Employees Initials: _____

westk@tennk12.net 61029468-2p9r



Certificate of Completion

Chester County School System

Laura Poe

has completed

Asbestos Awareness (K-12 Full 2 Hour)

a training program requiring 2 hours

on

Monday, November 11, 2013


Training Coordinator's Signature

Employees Initials: _____

westk@kenk12.net 61029468-2p9r



Certificate of Completion

Chester County School System

Shane Burkeens

has completed

Asbestos Awareness (K-12 Full 2 Hour)

a training program requiring 2 hours

on

Monday, November 11, 2013


Training Coordinator's Signature

Employees Initials: _____

westk@tennk12.net 61029468-2p9r



**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 1-20-10

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): GARY W. GRISHAM

SURVEILLANCE INSPECTOR'S SIGNATURE: Gay W. Wickham
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): ASBBIR0902047 / TN

TAHERA 9.0 (2/97)

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: MARCH 2010

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 1988

INSPECTION DATE: 03/16/2010



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
X	X	X	X	X	X	X	X

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X

ASSESSMENT (MARK FROM 1 TO 7)

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

STEPHANIE PETTY
INSPECTOR (Typed Name)

SIGNATURE

ASBBIR0910310/TN
ACCREDITATION #/STATE

STEVE CHAMBLISS
MANAGEMENT PLANNER

SIGNATURE

ASBMPR1002145/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 1988

INSPECTION DATE: 03/16/2010



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

HA NUMBER		HA NUMBER		HA NUMBER		HA NUMBER	
CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
MATERIAL DESCRIPTION		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION	
2x4 Ceiling Tile							
LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X						
X	X						
X	X						
1	1						
1	1						
1	1						
1	1						
1	1						
1	1						
X	X						
X	X						
X	X						
7	7						
B	B						

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"> A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate | <ul style="list-style-type: none"> E. Enclosure F. Remove G. Isolate H. Other |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

STEPHANIE PETTY
 INSPECTOR (Typed Name)

SIGNATURE

ASBBIR0910310/TN
 ACCREDITATION #/STATE

STEVE CHAMBLISS
 MANAGEMENT PLANNER

SIGNATURE

ASBMPIR1002145/TN
 ACCREDITATION #/STATE

STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM

DATE: 5/19/2011

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: CHESTER COUNTY JUNIOR HIGH

SCHOOL NO.: 126-0010

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West

SURVEILLANCE INSPECTOR'S SIGNATURE: [Signature]
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable):

ATHERA 9.0 (2/97)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: CHESTER COUNTY MIDDLE SCHOOL

SCHOOL NO.: 120-005

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date 5/18-11 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
5A	Floor tile	All	Good	N/C	
6	Floor tile	All	Good	N/C	
7A	Pipe Insulation	All	Good	N/C	
7B	Floor tile	All	Good	N/C	
8	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	
9A	Pipe Insulation	All	Good	N/C	
9B	Boiler wrap Insulation	All	Good	N/C	
9C	H2O Tank Insulation	N/A	N/A	Tank removed in '99	
	2x4 Ceiling tile	All	Good	N/C	
10A	Boiler Jacket	All	Good	N/C	
10B	Pipe Insulation	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

LEA NAME: CHESTER COUNTY BOELEA NO: 120SCHOOL NAME: CHESTER COUNTY MIDDLE SCHOOLSCHOOL NO.: 120-005BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date 5/18/11 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
10C	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	
12	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	
13A	Floor tile	All	Good	N/C	
13B	Pipe Insulation	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/CSURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

TAHERA 9.0 (2/97)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: EAST CHESTER ELEMENTARY

SCHOOL NO.: 120-0015

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date: 5/18/11 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
5	Floor tile	All	Good	N/C	
6	Floor tile	All	Good	N/C	
7	Floor tile	All	Good	N/C	
8	Floor tile	All	Good	N/C	
9	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: WEST CHESTER ELEMENTARY

SCHOOL NO.: 120-030

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
5	Floor tile	All	Good	N/C	
6	2X4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date (Fall)	2nd six months Date 5/19/11 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: NORTH CHESTER ELEMENTARY

SCHOOL NO.: NA

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date 5/18/11 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
5	Floor tile	All	Good	N/C	
6	Floor tile	All	Good	N/C	
7	Floor tile	All	Good	N/C	
8	Floor tile	All	Good	N/C	
	2x4 Ceiling Tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 11/21/11

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date 11/18/2011 (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 5-17-2012

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>11/18/2011</u> (Fall)	2nd six months Date <u>5-16-12</u> (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 12/04/12

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		SIX MONTH PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>12/03/2012</u> (Fall)	2nd six months Date _____ (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 4-11-13

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT/ SIX MONTH
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date: 4-9-13 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All		N/C	
2	Floor tile	All		N/C	
3	Floor tile	All		N/C	
4	Floor tile	All		N/C	
	2x4 Ceiling tile	All		N/C	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 10-15-13

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: 970 East Main St. Henderson, TN 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle School

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle School

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
9A	9B	9C	
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Pipe Insulation	Boiler wrap Insulation	H2O Tank Insulation	2x4 Ceiling Tile

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI	X	X	X	X	X	X		
SURFACING								
MISCELLANEOUS							X	X

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
ASSUMED ACBM							X	X
CONFIRMED ACBM	X	X	X	X	X	X		
NON-ACBM								

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
NON-FRIABLE								
FRIABLE	X	X	X	X	X	X	X	X

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
DETERIORATION	2	2	2	2	2	2	2	2
PHYSICAL DAMAGE	1	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2
EXPOSURE	1	1	1	1	1	1	1	1
ACCESSIBILITY	1	1	1	1	1	1	1	1

LENGTH OF EXPOSURE (CHECK ONE)	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
1 HOUR/WEEK	X	X	X	X	X	X	X	X
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK								

EXPOSURE POPULATION (CHECK ALL APPLICABLE)	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
MAINTENANCE	X	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X	X
FACULTY/STAFF								
PUBLIC								

ASSESSMENT (MARK FROM 1 TO 7)	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
	5	5	5	5	5	5	7	7

**RESPONSE ACTIONS (MARK FROM A TO H)	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
	B	B	B	B	B	B	B	B

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle

Building #: Cafe

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- A. Institute preventative measures
- B. O & M Program
- C. Repair
- D. Encapsulate

- E. Enclosure
- F. Remove
- G. Isolate
- H. Other

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle School

Building #: AGRI

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION	2	2	2	2	1	1	2	2
PHYSICAL DAMAGE	1	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2
EXPOSURE	1	1	1	1	1	1	1	1
ACCESSIBILITY	1	1	1	1	1	1	1	1

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK	X	X	X	X			X	X
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK					X	X		

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X	X
FACULTY/STAFF					X	X		
PUBLIC					X	X		

ASSESSMENT (MARK FROM 1 TO 7)

5	5	5	5	5	5	5	7	7
---	---	---	---	---	---	---	---	---

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

- Damaged/significantly damaged TSI
- Damaged friable surfacing ACBM
- Significantly damaged friable surfacing material
- Damaged/significantly damaged friable misc. ACBM
- ACBM with potential for damage
- ACBM with potential for significant damage
- Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

* If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle

Building #: Buisness

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
12			
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	2x4 Ceiling Tile		

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X				

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

		X	X				
X	X						

CHECK ONE

NON-FRIABLE
FRIABLE

X	X						
		X	X				

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION	1	1	1	1			
PHYSICAL DAMAGE	1	1	1	1			
WATER DAMAGE	1	1	1	1			
ACTIVITY/VIBRATION	2	2	1	1			
EXPOSURE	2	2	1	1			
ACCESSIBILITY	1	1	1	1			

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK			X	X			
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK	X	X					

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X			
CUSTODIAL	X	X	X	X			
FACULTY/STAFF	X	X					
PUBLIC	X	X					

ASSESSMENT (MARK FROM 1 TO 7)

5	5	7	7				
---	---	---	---	--	--	--	--

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B	B	B				
---	---	---	---	--	--	--	--

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Chester County Middle

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
13A	13B		
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	Pipe Insulation	2x4 Ceiling Tile	

CHECK ONE

TSI
SURFACING
MISCELLANEOUS

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
		X	X				
X	X			X	X		

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

				X	X		
X	X	X	X				

CHECK ONE

NON-FRIABLE
FRIABLE

X	X						
		X	X	X	X		

EXPOSURE CONSIDERATION (1 TO 5 (5 WORST))

DETERIORATION	1	1	2	2	1	1		
PHYSICAL DAMAGE	1	1	2	2	1	1		
WATER DAMAGE	1	1	1	1	1	1		
ACTIVITY/VIBRATION	2	2	1	1	1	1		
EXPOSURE	2	2	1	1	1	1		
ACCESSIBILITY	1	1	1	1	1	1		

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK			X	X	X	X		
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK	X	X						

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X	X	X		
CUSTODIAL	X	X	X	X	X	X		
FACULTY/STAFF	X	X						
PUBLIC	X	X						

ASSESSMENT (MARK FROM 1 TO 7)

5	5	5	5	7	7		
---	---	---	---	---	---	--	--

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B	B	B	B	B		
---	---	---	---	---	---	--	--

ASSESSMENT LEGEND

- Damaged/significantly damaged TSI
- Damaged friable surfacing ACBM
- Significantly damaged friable surfacing material
- Damaged/significantly damaged friable misc. ACBM
- ACBM with potential for damage
- ACBM with potential for significant damage
- Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

* If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: East Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

ASSESSMENT (MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1 HOUR/WEEK							
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK	X	X	X	X	X	X	X
MAINTENANCE	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X
FACULTY/STAFF	X	X	X	X	X	X	X
PUBLIC	X	X	X	X	X	X	X
5	5	5	5	5	5	5	5
B	B	B	B	B	B	B	B

ASSESSMENT LEGEND

- Damaged/significantly damaged TSI
- Damaged friable surfacing ACBM
- Significantly damaged friable surfacing material
- Damaged/significantly damaged friable misc. ACBM
- ACBM with potential for damage
- ACBM with potential for significant damage
- Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: East Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

ASSESSMENT (MARK FROM 1 TO 7)

**RESPONSE ACTIONS (MARK FROM A TO H)

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

- *If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

Stephanie Petty
SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: East Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

CHECK ONE

NON-FRIABLE
FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION
PHYSICAL DAMAGE
WATER DAMAGE
ACTIVITY/VIBRATION
EXPOSURE
ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR/WEEK
5 HOUR/WEEK
10 HOUR/WEEK
20 HOUR/WEEK
40 HOUR/WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE
CUSTODIAL
FACULTY/STAFF
PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS

(MARK FROM A TO H)

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS

(MARK FROM A TO H)

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
2x4 Ceiling Tile			

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X						

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

X	X						

CHECK ONE

NON-FRIABLE
FRIABLE

X	X						

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION	1	1					
PHYSICAL DAMAGE	1	1					
WATER DAMAGE	1	1					
ACTIVITY/VIBRATION	1	1					
EXPOSURE	1	1					
ACCESSIBILITY	1	1					

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK	X	X					
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK							

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X					
CUSTODIAL	X	X					
FACULTY/STAFF							
PUBLIC							

ASSESSMENT (MARK FROM 1 TO 7)

7	7						
---	---	--	--	--	--	--	--

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B						
---	---	--	--	--	--	--	--

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: North Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
2	3	4	5
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	Floor Tile	Floor Tile	Floor Tile

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

X	X	X	X	X	X	X	X

CHECK ONE

NON-FRIABLE
FRIABLE

X	X	X	X	X	X	X	X

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION	1	1	1	1	1	1	1
PHYSICAL DAMAGE	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2	2	2	2
EXPOSURE	1	1	1	1	1	1	1
ACCESSIBILITY	1	1	1	1	1	1	1

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK							
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK	X	X	X	X	X	X	X

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X
FACULTY/STAFF	X	X	X	X	X	X	X
PUBLIC	X	X	X	X	X	X	X

ASSESSMENT (MARK FROM 1 TO 7)

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

**RESPONSE ACTIONS (MARK FROM A TO H)

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

- Damaged/significantly damaged TSI
- Damaged friable surfacing ACBM
- Significantly damaged friable surfacing material
- Damaged/significantly damaged friable misc. ACBM
- ACBM with potential for damage
- ACBM with potential for significant damage
- Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

- * If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
- ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: North Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
6	7	8	
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	Floor Tile	Floor Tile	2x4 Ceiling Tile

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

						X	X
X	X	X	X	X	X		

CHECK ONE

NON-FRIABLE
FRIABLE

X	X	X	X	X	X		
						X	X

EXPOSURE CONSIDERATION (1 TO 5 (5 WORST))

DETERIORATION	1	1	1	1	1	1	1
PHYSICAL DAMAGE	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2	2	2	1
EXPOSURE	1	1	1	1	1	1	1
ACCESSIBILITY	1	1	1	1	1	1	1

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK							X	X
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK	X	X	X	X	X	X		

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X	X
FACULTY/STAFF	X	X	X	X	X	X		
PUBLIC	X	X	X	X	X	X		

ASSESSMENT

(MARK FROM 1 TO 7)

5	5	5	5	5	5	7	7
---	---	---	---	---	---	---	---

**RESPONSE ACTIONS

(MARK FROM A TO H)

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

- Damaged/significantly damaged TSI
- Damaged friable surfacing ACBM
- Significantly damaged friable surfacing material
- Damaged/significantly damaged friable misc. ACBM
- ACBM with potential for damage
- ACBM with potential for significant damage
- Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: West Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS

(MARK FROM A TO H)

HA NUMBER		HA NUMBER		HA NUMBER		HA NUMBER	
1		2		3		4	
CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
MATERIAL DESCRIPTION		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION	
Floor Tile		Floor Tile		Floor Tile		Floor Tile	
LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
5	5	5	5	5	5	5	5
B	B	B	B	B	B	B	B

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: West Chester Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI
SURFACING
MISCELLANEOUS

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
5	6		
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	2x4 Ceiling Tile		

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X				

CHECK ONE

ASSUMED ACBM
CONFIRMED ACBM
NON-ACBM

		X	X				
X	X						

CHECK ONE

NON-FRIABLE
FRIABLE

X	X						
		X	X				

EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)

DETERIORATION	1	1	1	1			
PHYSICAL DAMAGE	1	1	1	1			
WATER DAMAGE	1	1	1	1			
ACTIVITY/VIBRATION	2	2	1	1			
EXPOSURE	2	2	1	1			
ACCESSIBILITY	1	1	1	1			

LENGTH OF EXPOSURE (CHECK ONE)

1 HOUR/WEEK			X	X			
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK	X	X					

EXPOSURE POPULATION (CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X			
CUSTODIAL	X	X	X	X			
FACULTY/STAFF	X	X					
PUBLIC	X	X					

ASSESSMENT

(MARK FROM 1 TO 7)

5	5	7	7				
---	---	---	---	--	--	--	--

**RESPONSE ACTIONS

(MARK FROM A TO H)

B	B	B	B				
---	---	---	---	--	--	--	--

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- | | |
|------------------------------------|--------------|
| A. Institute preventative measures | E. Enclosure |
| B. O & M Program | F. Remove |
| C. Repair | G. Isolate |
| D. Encapsulate | H. Other |

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0
** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 10-15-13

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: 970 East Main St. Henderson, TN 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

THREE YEAR REINSPECTION

LEA NAME: Chester County BOE

LEA #: 120

School Building Name: Jacks Creek Elementary

Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN:

INSPECTION DATE: 10/15/13



CHECK ONE

TSI

SURFACING

MISCELLANEOUS

CHECK ONE

ASSUMED ACBM

CONFIRMED ACBM

NON-ACBM

CHECK ONE

NON-FRIABLE

FRIABLE

EXPOSURE CONSIDERATION

1 TO 5 (5 WORST)

DETERIORATION

PHYSICAL DAMAGE

WATER DAMAGE

ACTIVITY/VIBRATION

EXPOSURE

ACCESSIBILITY

LENGTH OF EXPOSURE

(CHECK ONE)

1 HOUR/WEEK

5 HOUR/WEEK

10 HOUR/WEEK

20 HOUR/WEEK

40 HOUR/WEEK

EXPOSURE POPULATION

(CHECK ALL APPLICABLE)

MAINTENANCE

CUSTODIAL

FACULTY/STAFF

PUBLIC

ASSESSMENT

(MARK FROM 1 TO 7)

**RESPONSE ACTIONS

(MARK FROM A TO H)

HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
1	2	3	4
CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY

MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
Floor Tile	Floor Tile	Floor Tile	Floor Tile

LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X

1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1
2	2	2	2	2	2	2	2
1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1

X	X	X	X	X	X	X	X

X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X
X	X	X	X	X	X	X	X

5	5	5	5	5	5	5	5
---	---	---	---	---	---	---	---

B	B	B	B	B	B	B	B
---	---	---	---	---	---	---	---

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

- A. Institute preventative measures
- B. O & M Program
- C. Repair
- D. Encapsulate

- E. Enclosure
- F. Remove
- G. Isolate
- H. Other

NOTES

*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Stephanie Petty
INSPECTOR (Typed Name)

SIGNATURE

Stephanie Petty
MANAGEMENT PLANNER

SIGNATURE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

A-MP-47891-26076/TN
ACCREDITATION #/STATE

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 5-6-2014

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		SIX MONTH PROGRESS REPORT
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date 10-15-14 (Fall)	2nd six months Date 5-6-14 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 11-11-2014

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
✓		YEARLY PROGRESS REPORT <u>6 mos</u>
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>11-11-16</u> (Fall)	2nd six months Date _____ (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 4-7-2015

LEA SYSTEM NAME: Chester County Schools LEA#: 120

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Mr. Ken West PHONE: 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT <i>6 mo. Periodic Inspection</i>
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date _____ (Fall)	2nd six months Date _____ (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	N/C	
2	Floor tile	All	Good	N/C	
3	Floor tile	All	Good	N/C	
4	Floor tile	All	Good	N/C	
	2x4 Ceiling tile	All	Good	N/C	

SURVEILLANCE INSPECTOR'S NAME (please print): Ken West *IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S SIGNATURE: Ken West
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

emailed to:
Deborah.Gunter@tn.gov.
10/13/15 9:02 am

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: 10/13/15

LEA SYSTEM NAME: Chester County Schools **LEA#: 120**

ADDRESS: PO Box 327, Henderson, Tennessee 38340

DESIGNATED PERSON: Britt Eads **PHONE:** 731-989-5134

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
X		YEARLY PROGRESS REPORT/ SIX MONTH
		THREE YEAR REINSPECTION
		OTHER (Please Explain)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>10/9/2015</u> (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good		
2	Floor tile	All	Good		
3	Floor tile	All	Good		
4	Floor tile	All	Good		
	2x4 Ceiling tile	All	Good		

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____



February 24, 2016

Mr. Britt Eads
Chester County Schools
970 East Main Street
Henderson, Tennessee 38340
eadsb01@120cc.org
(731) 433-7266

**RE: CHESTER COUNTY SCHOOLS
2016 AHERA THREE YEAR REINSPECTION REPORT
PROJECT NO. 804416**

Mr. Eads:

Enclosed is the three year reinspection report for the schools inspected on February 23, 2016. Please have the school superintendent sign the Assurances Page (TAHERA 3.0).

A copy of this report has been submitted to the following address:

*Tennessee Department of Education
Division of Finance, Accountability and Technology
Budget and Planning
6TH Floor, Andrew Johnson Tower
710 James Robertson Parkway
Nashville, Tennessee 37243-0375
Attention: Deborah Boshears-Davis*

Keep the original report with your management plan and submit a copy to each school under the current O & M Plan. Your next inspection (periodic surveillance inspection) will be in August 2016.

Should you have any questions or require additional information, please feel free to call my office at (615) 865-8813 or my cell at (615) 478-2463.

Sincerely,

RESOLUTION, INC.

Christopher R. Johnson, PG
Manager

Attch: 2016 AHERA Three Year Reinspection Report

**STATE OF TENNESSEE
AHERA TRANSMITTAL/SUBMITTAL FORM**

DATE: February 24, 2016

LEA SYSTEM NAME: Chester County Schools **LEA#:** 120

ADDRESS: 970 East Main Street, Henderson, TN 38340

DESIGNATED PERSON: Mr. Britt Eads **PHONE:** (731) 433-7266

**PLEASE INDICATE TYPE OF DOCUMENT(S) BEING SUBMITTED
BY PLACING AN "X" IN THE APPROPRIATE BOX**

ORIGINAL SUBMISSION	CORRECTION/DEFICIENCY SUBMISSION	TYPE OF DOCUMENT
		MANAGEMENT PLAN
		ASBESTOS FREE MANAGEMENT PLAN
		YEARLY PROGRESS REPORT
X		THREE YEAR REINSPECTION
		OTHER (Please Explain)

ASSURANCES

SCHOOL YEAR ENDING: 2016

LEA SYSTEM NAME: Chester County Schools

LEA NO.: 120

This AHERA Management Plan was developed and has been submitted pursuant to the Asbestos Hazard Emergency Response Act of 1986. Public Law 99-519; and the United States Environment Protection Agency Rule: Asbestos Containing Material in Schools; 40 CFR Part 763, Subpart E; and the undersigned does hereby certify that the Local Education Agency (LEA) indicated below has and will ensure the following:

1. The activities of any persons who perform inspections, re-inspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Part 763 and other Federal and State regulations and requirements.
2. All custodial and maintenance employees are properly trained as required in Part 763 and all other applicable Federal and State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule or applicable State regulations).
3. All workers and building occupants, and their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic re-inspection and surveillance activities, that are planned or in progress.
4. All short term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of asbestos-containing materials (ACM).
5. All warning labels are posted in accordance with Section 763.93 (g).
6. All management plans are available for inspection and notification of such availability has been provided as specified in the AHERA regulations under Paragraph 763.84 (g) (2).
7. The undersigned person designated by the LEA pursuant to Paragraph 763.84 (g) (1) has received adequate training as stipulated in Paragraph 763.84 (g) (2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship between the Management Planner and other accredited persons performing AHERA activities.

LEA DESIGNATED PERSON (please print): Britt Eads

LEA DESIGNATED PERSON'S SIGNATURE: 

DATE: 3/2/16

SUPERINTENDENT (please print): TROY KILZER II

SUPERINTENDENT SIGNATURE: 

DATE: 3/3/16

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Middle School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
		CURRENT QUANTITY 150 SF		CURRENT QUANTITY 1488 SF		CURRENT QUANTITY 70 SF		CURRENT QUANTITY 2960	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	

	LAST 3 YEAR		CURRENT		LAST 3 YEAR		CURRENT		LAST 3 YEAR		CURRENT		LAST 3 YEAR		CURRENT	
CHECK ONE																
TSI																
SURFACING																
MISCELLANEOUS	X		X		X		X		X		X		X		X	
CHECK ONE																
ASSUMED ACBM																
CONFIRMED ACBM	X		X		X		X		X		X		X		X	
NON-ACBM																
CHECK ONE																
NON-FRIABLE	X		X		X		X		X		X		X		X	
FRIABLE																
EXPOSURE CONSIDERATION																
1 TO 5 (5 WORST)																
DETERIORATION	1		1		1		1		1		1		1		1	
PHYSICAL DAMAGE	1		1		1		1		1		1		1		1	
WATER DAMAGE	1		1		1		1		1		1		1		1	
ACTIVITY/VIBRATION	2		2		2		2		2		2		2		2	
EXPOSURE	1		1		1		1		1		1		1		1	
ACCESSIBILITY	1		1		1		1		1		1		1		1	
LENGTH OF EXPOSURE																
(CHECK ONE)																
1 HOUR/WEEK																
5 HOUR/WEEK																
10 HOUR/WEEK																
20 HOUR/WEEK																
40 HOUR/WEEK	X		X		X		X		X		X		X		X	
EXPOSURE POPULATION																
(CHECK ALL APPLICABLE)																
MAINTENANCE	X		X		X		X		X		X		X		X	
CUSTODIAL	X		X		X		X		X		X		X		X	
FACULTY/STAFF	X		X		X		X		X		X		X		X	
PUBLIC	X		X		X		X		X		X		X		X	
ASSESSMENT																
(MARK FROM 1 TO 7)																
	5		5		5		5		5		5		5		5	
**RESPONSE ACTIONS																
(MARK FROM A TO H)																
	B		B		B		B		B		B		B		B	

ASSESSMENT LEGEND	RESPONSE ACTIONS LEGEND
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM	A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other
NOTES *If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5	

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Middle School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 5A		HA NUMBER 6		HA NUMBER 7A		HA NUMBER 7B	
		CURRENT QUANTITY 6250 SF		CURRENT QUANTITY 5849 SF		CURRENT QUANTITY 600 LF		CURRENT QUANTITY 12832	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Pipe Insulation		MATERIAL DESCRIPTION Floor Tile	

	LAST 3 YEAR		CURRENT		LAST 3 YEAR		CURRENT		LAST 3 YEAR		CURRENT	
CHECK ONE												
TSI						X	X					
SURFACING												
MISCELLANEOUS	X		X		X		X		X		X	
CHECK ONE												
ASSUMED ACBM												
CONFIRMED ACBM	X		X		X		X		X		X	
NON-ACBM												
CHECK ONE												
NON-FRIABLE	X		X		X		X		X		X	
FRIABLE						X	X					
EXPOSURE CONSIDERATION												
1 TO 5 (5 WORST)												
DETERIORATION	1		1		1		1		1		1	
PHYSICAL DAMAGE	1		1		1		1		1		1	
WATER DAMAGE	1		1		1		1		1		1	
ACTIVITY/VIBRATION	2		2		2		2		2		2	
EXPOSURE	1		1		1		1		1		1	
ACCESSIBILITY	1		1		1		1		1		1	
LENGTH OF EXPOSURE												
(CHECK ONE)												
1 HOUR/WEEK												
5 HOUR/WEEK						X	X					
10 HOUR/WEEK												
20 HOUR/WEEK												
40 HOUR/WEEK	X		X		X		X		X		X	
EXPOSURE POPULATION												
(CHECK ALL APPLICABLE)												
MAINTENANCE	X		X		X		X		X		X	
CUSTODIAL	X		X		X		X		X		X	
FACULTY/STAFF	X		X		X				X		X	
PUBLIC	X		X		X				X		X	
ASSESSMENT												
(MARK FROM 1 TO 7)												
	5		5		5		5		5		5	
**RESPONSE ACTIONS												
(MARK FROM A TO H)												
	B		B		B		B		B		B	

ASSESSMENT LEGEND	RESPONSE ACTIONS LEGEND
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM	A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other
NOTES	
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5	

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County SchoolsLEA #: 120School Building Name: Chester County Middle SchoolBuilding #: MainDATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89INSPECTION DATE: 2/23/16

	HA NUMBER 9A	HA NUMBER 9B	HA NUMBER 9C	HA NUMBER
	CURRENT QUANTITY 150 SF	CURRENT QUANTITY 160 SF	CURRENT QUANTITY 120 LF	CURRENT QUANTITY Throughout
	MATERIAL DESCRIPTION Pipe Insulation	MATERIAL DESCRIPTION Boiler Wrap Insulation	MATERIAL DESCRIPTION Water Tank Insulation	MATERIAL DESCRIPTION 2x4 Ceiling Tile
CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI	X	X	X	X
SURFACING				
MISCELLANEOUS				X
CHECK ONE				
ASSUMED ACBM				X
CONFIRMED ACBM	X	X	X	X
NON-ACBM				
CHECK ONE				
NON-FRIABLE				
FRIABLE	X	X	X	X
EXPOSURE CONSIDERATION				
1 TO 5 (5 WORST)				
DETERIORATION	2	2	2	2
PHYSICAL DAMAGE	1	1	1	1
WATER DAMAGE	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2
EXPOSURE	1	1	1	1
ACCESSIBILITY	1	1	1	1
LENGTH OF EXPOSURE				
(CHECK ONE)				
1 HOUR/WEEK	X	X	X	X
5 HOUR/WEEK				
10 HOUR/WEEK				
20 HOUR/WEEK				
40 HOUR/WEEK				
EXPOSURE POPULATION				
(CHECK ALL APPLICABLE)				
MAINTENANCE	X	X	X	X
CUSTODIAL	X	X	X	X
FACULTY/STAFF				
PUBLIC				
ASSESSMENT				
(MARK FROM 1 TO 7)				
	5	5	5	7
**RESPONSE ACTIONS				
(MARK FROM A TO H)				
	B	B	B	B
ASSESSMENT LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACDM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM				
RESPONSE ACTIONS LEGEND				
A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
NOTES				
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Middle School Building #: Cafe

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 8		HA NUMBER		HA NUMBER		HA NUMBER	
		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION 2x4 Ceiling Tile		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION	
CHECK ONE TSI SURFACING MISCELLANEOUS	LAST 3 YEAR		CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
	X	X	X	X					
CHECK ONE									
ASSUMED ACBM CONFIRMED ACBM NON-ACBM			X	X					
	X	X							
CHECK ONE									
NON-FRIABLE FRIABLE	X	X							
			X	X					
EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)									
DETERIORATION	1	1	1	1					
PHYSICAL DAMAGE	1	1	1	1					
WATER DAMAGE	1	1	1	1					
ACTIVITY/VIBRATION	3	3	1	1					
EXPOSURE	2	2	1	1					
ACCESSIBILITY	1	1	1	1					
LENGTH OF EXPOSURE (CHECK ONE)									
1 HOUR/WEEK			X	X					
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK	X	X							
EXPOSURE POPULATION (CHECK ALL APPLICABLE)									
MAINTENANCE	X	X	X	X					
CUSTODIAL	X	X	X	X					
FACULTY/STAFF	X	X							
PUBLIC	X	X							
ASSESSMENT (MARK FROM 1 TO 7)									
	5	5	7	7					
**RESPONSE ACTIONS (MARK FROM A TO H)									
	B	B	B	B					
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
					NOTES				
					*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Middle School Building #: Agri

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

	HA NUMBER 10	HA NUMBER 10B	HA NUMBER 10C	HA NUMBER
	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
	MATERIAL DESCRIPTION Boiler Jacket	MATERIAL DESCRIPTION Pipe Insulation	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION 2x4 Ceiling Tile
CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI	X	X	X	X
SURFACING				
MISCELLANEOUS			X	X
CHECK ONE				
ASSUMED ACBM				X
CONFIRMED ACBM	X	X	X	X
NON-ACBM				
CHECK ONE				
NON-FRIABLE			X	X
FRIABLE	X	X	X	X
EXPOSURE CONSIDERATION				
1 TO 5 (5 WORST)				
DETERIORATION	2	2	2	2
PHYSICAL DAMAGE	1	1	1	1
WATER DAMAGE	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2
EXPOSURE	1	1	1	1
ACCESSIBILITY	1	1	1	1
LENGTH OF EXPOSURE				
(CHECK ONE)				
1 HOUR/WEEK	X	X	X	X
5 HOUR/WEEK				
10 HOUR/WEEK				
20 HOUR/WEEK				
40 HOUR/WEEK			X	X
EXPOSURE POPULATION				
(CHECK ALL APPLICABLE)				
MAINTENANCE	X	X	X	X
CUSTODIAL	X	X	X	X
FACULTY/STAFF			X	X
PUBLIC			X	X
ASSESSMENT				
(MARK FROM 1 TO 7)				
	5	5	5	5
**RESPONSE ACTIONS				
(MARK FROM A TO H)				
	B	B	B	B
ASSESSMENT LEGEND				
RESPONSE ACTIONS LEGEND				
<div> 1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM </div> <div> A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate </div> <div> E. Enclosure F. Remove G. Isolate H. Other </div>				
NOTES				
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Middle School Building #: Business

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

	HA NUMBER 12	HA NUMBER	HA NUMBER	HA NUMBER
	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION 2x4 Ceiling Tile	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION

	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
CHECK ONE								
TSI								
SURFACING								
MISCELLANEOUS	X	X	X	X				
CHECK ONE								
ASSUMED ACBM			X	X				
CONFIRMED ACBM	X	X						
NON-ACBM								
CHECK ONE								
NON-FRIABLE	X	X						
FRIABLE			X	X				
EXPOSURE CONSIDERATION								
1 TO 5 (5 WORST)								
DETERIORATION	1	1	1	1				
PHYSICAL DAMAGE	1	1	1	1				
WATER DAMAGE	1	1	1	1				
ACTIVITY/VIBRATION	2	2	1	1				
EXPOSURE	2	2	1	1				
ACCESSIBILITY	1	1	1	1				
LENGTH OF EXPOSURE								
(CHECK ONE)								
1 HOUR/WEEK			X	X				
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK	X	X						
EXPOSURE POPULATION								
(CHECK ALL APPLICABLE)								
MAINTENANCE	X	X	X	X				
CUSTODIAL	X	X	X	X				
FACULTY/STAFF	X	X						
PUBLIC	X	X						
ASSESSMENT								
(MARK FROM 1 TO 7)								
	5	5	7	7				
**RESPONSE ACTIONS								
(MARK FROM A TO H)								
	B	B	B	B				

ASSESSMENT LEGEND	RESPONSE ACTIONS LEGEND
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM	A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other
NOTES *If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5	

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA #: 120Building #: Main INSPECTION DATE: 2/23/16

HA NUMBER 13		HA NUMBER 13B		HA NUMBER		HA NUMBER	
CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY		CURRENT QUANTITY	
MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Pipe Insulation		MATERIAL DESCRIPTION 2x4 Ceiling Tile		MATERIAL DESCRIPTION	
CHECK ONE TSI SURFACING MISCELLANEOUS	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR
			X	X			
	X	X			X	X	
CHECK ONE ASSUMED ACBM CONFIRMED ACBM NON-ACBM					X	X	
	X	X	X	X			
CHECK ONE NON-FRIABLE FRIABLE	X	X					
			X	X	X	X	
EXPOSURE CONSIDERATION 1 TO 5 (5 WORST)							
DETERIORATION	1	1	2	2	1	1	
PHYSICAL DAMAGE	1	1	2	2	1	1	
WATER DAMAGE	1	1	1	1	1	1	
ACTIVITY/VIBRATION	2	2	1	1	1	1	
EXPOSURE	2	2	1	1	1	1	
ACCESSIBILITY	1	1	1	1	1	1	
LENGTH OF EXPOSURE (CHECK ONE)							
1 HOUR/WEEK			X	X	X	X	
5 HOUR/WEEK							
10 HOUR/WEEK							
20 HOUR/WEEK							
40 HOUR/WEEK	X	X					
EXPOSURE POPULATION (CHECK ALL APPLICABLE)							
MAINTENANCE	X	X	X	X	X	X	
CUSTODIAL	X	X	X	X	X	X	
FACULTY/STAFF	X	X					
PUBLIC	X	X					
ASSESSMENT (MARK FROM 1 TO 7)							
	5	5	5	5	7	7	
**RESPONSE ACTIONS (MARK FROM A TO H)							
	B	B	B	B	B	B	
ASSESSMENT LEGEND				RESPONSE ACTIONS LEGEND			
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM				A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other			
NOTES							
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5							

SIGNATURE

SIGNATURE

Christina K. Jol

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: West Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
		CURRENT QUANTITY 1770 SF		CURRENT QUANTITY 2140 SF		CURRENT QUANTITY 5603 SF		CURRENT QUANTITY 6240 SF	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE	TSI	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
	SURFACING								
	MISCELLANEOUS								
	CHECK ONE								
	ASSUMED ACBM								
	CONFIRMED ACBM								
	NON-ACBM								
CHECK ONE	NON-FRIABLE								
	FRIABLE								
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
	DETERIORATION	1	1	1	1	1	1	1	1
	PHYSICAL DAMAGE	1	1	1	1	1	1	1	1
	WATER DAMAGE	1	1	1	1	1	1	1	1
	ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2
	EXPOSURE	1	1	1	1	1	1	1	1
	ACCESSIBILITY	1	1	1	1	1	1	1	1
LENGTH OF EXPOSURE									
(CHECK ONE)									
	1 HOUR/WEEK								
	5 HOUR/WEEK								
	10 HOUR/WEEK								
	20 HOUR/WEEK								
	40 HOUR/WEEK	X	X	X	X	X	X	X	X
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
	MAINTENANCE	X	X	X	X	X	X	X	X
	CUSTODIAL	X	X	X	X	X	X	X	X
	FACULTY/STAFF	X	X	X	X	X	X	X	X
	PUBLIC	X	X	X	X	X	X	X	X
ASSESSMENT									
(MARK FROM 1 TO 7)									
		5	5	5	5	5	5	5	5
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
		B	B	B	B	B	B	B	B
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson
INSPECTOR (Typed Name)


SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER


SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: West Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 5		HA NUMBER 6		HA NUMBER		HA NUMBER	
		CURRENT QUANTITY		CURRENT QUANTITY 30,000 SF		CURRENT QUANTITY		CURRENT QUANTITY	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION 2x4 Ceiling Tile		MATERIAL DESCRIPTION		MATERIAL DESCRIPTION	
CHECK ONE TSI SURFACING MISCELLANEOUS	LAST 3 YEAR			LAST 3 YEAR		LAST 3 YEAR		LAST 3 YEAR	
	CURRENT			CURRENT		CURRENT		CURRENT	
		X	X		X				
CHECK ONE ASSUMED ACBM CONFIRMED ACBM NON-ACBM				X	X				
		X	X						
CHECK ONE NON-FRIABLE FRIABLE		X	X						
				X	X				
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION	1	1	1	1					
PHYSICAL DAMAGE	1	1	1	1					
WATER DAMAGE	1	1	1	1					
ACTIVITY/VIBRATION	2	2	1	1					
EXPOSURE	2	2	1	1					
ACCESSIBILITY	1	1	1	1					
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK			X	X					
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK	X	X							
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE	X	X	X	X					
CUSTODIAL	X	X	X	X					
FACULTY/STAFF	X	X							
PUBLIC	X	X							
ASSESSMENT									
(MARK FROM 1 TO 7)									
	5	5	7	7					
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
	B	B	B	B					
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
					NOTES				
					*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: North Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4		HA NUMBER 5	
		CURRENT QUANTITY 3904 SF		CURRENT QUANTITY 200 SF		CURRENT QUANTITY		CURRENT QUANTITY 4768	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE	TSI	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
	SURFACING								
	MISCELLANEOUS	X	X	X	X	X	X	X	X
CHECK ONE									
	ASSUMED ACBM								
	CONFIRMED ACBM	X	X	X	X	X	X	X	X
	NON-ACBM								
CHECK ONE									
	NON-FRIABLE	X	X	X	X	X	X	X	X
	FRIABLE								
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
	DETERIORATION	1	1	1	1	1	1	1	1
	PHYSICAL DAMAGE	1	1	1	1	1	1	1	1
	WATER DAMAGE	1	1	1	1	1	1	1	1
	ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2
	EXPOSURE	1	1	1	1	1	1	1	1
	ACCESSIBILITY	1	1	1	1	1	1	1	1
LENGTH OF EXPOSURE									
(CHECK ONE)									
	1 HOUR/WEEK								
	5 HOUR/WEEK								
	10 HOUR/WEEK								
	20 HOUR/WEEK								
	40 HOUR/WEEK	X	X	X	X	X	X	X	X
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
	MAINTENANCE	X	X	X	X	X	X	X	X
	CUSTODIAL	X	X	X	X	X	X	X	X
	FACULTY/STAFF	X	X	X	X	X	X	X	X
	PUBLIC	X	X	X	X	X	X	X	X
ASSESSMENT									
(MARK FROM 1 TO 7)									
		5	5	5	5	5	5	5	5
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
		B	B	B	B	B	B	B	B
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate				
					E. Enclosure F. Remove G. Isolate H. Other				
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: North Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 6		HA NUMBER 7		HA NUMBER 8		HA NUMBER	
		CURRENT QUANTITY 1870 SF		CURRENT QUANTITY 6669 SF		CURRENT QUANTITY 864		CURRENT QUANTITY Throughout	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION 2x4 Ceiling Tile	
CHECK ONE TSI SURFACING MISCELLANEOUS	LAST 3 YEAR								
	CURRENT								
		X	X	X	X	X	X	X	X
CHECK ONE ASSUMED ACBM CONFIRMED ACBM NON-ACBM	LAST 3 YEAR							X	X
	CURRENT	X	X	X	X	X	X		
CHECK ONE NON-FRIABLE FRIABLE	LAST 3 YEAR	X	X	X	X	X	X		
	CURRENT							X	X
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION	1	1	1	1	1	1	1	1	1
PHYSICAL DAMAGE	1	1	1	1	1	1	1	1	1
WATER DAMAGE	1	1	1	1	1	1	1	1	1
ACTIVITY/VIBRATION	2	2	2	2	2	2	2	1	1
EXPOSURE	1	1	1	1	1	1	1	1	1
ACCESSIBILITY	1	1	1	1	1	1	1	1	1
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK								X	X
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK	X	X	X	X	X	X	X		
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE	X	X	X	X	X	X	X	X	X
CUSTODIAL	X	X	X	X	X	X	X	X	X
FACULTY/STAFF	X	X	X	X	X	X	X		
PUBLIC	X	X	X	X	X	X	X		
ASSESSMENT									
(MARK FROM 1 TO 7)									
	5	5	5	5	5	5	5	7	7
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
	B	B	B	B	B	B	B	B	B
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson
INSPECTOR (Typed Name)

Christopher R. Johnson
MANAGEMENT PLANNER

Christopher R. Johnson
SIGNATURE
Christopher R. Johnson
SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: East Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
		CURRENT QUANTITY 3915 SF		CURRENT QUANTITY 576 SF		CURRENT QUANTITY 7204 SF		CURRENT QUANTITY 1192 SF	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	
TSI									
SURFACING									
MISCELLANEOUS	X	X	X	X	X	X	X	X	
CHECK ONE									
ASSUMED ACBM									
CONFIRMED ACBM	X	X	X	X	X	X	X	X	
NON-ACBM									
CHECK ONE									
NON-FRIABLE	X	X	X	X	X	X	X	X	
FRIABLE									
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION	1	1	1	1	1	1	1	1	
PHYSICAL DAMAGE	1	1	1	1	1	1	1	1	
WATER DAMAGE	1	1	1	1	1	1	1	1	
ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2	
EXPOSURE	1	1	1	1	1	1	1	1	
ACCESSIBILITY	1	1	1	1	1	1	1	1	
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK									
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK	X	X	X	X	X	X	X	X	
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE	X	X	X	X	X	X	X	X	
CUSTODIAL	X	X	X	X	X	X	X	X	
FACULTY/STAFF	X	X	X	X	X	X	X	X	
PUBLIC	X	X	X	X	X	X	X	X	
ASSESSMENT									
(MARK FROM 1 TO 7)									
	5	5	5	5	5	5	5	5	
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
	B	B	B	B	B	B	B	B	
ASSESSMENT LEGEND									
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM									
RESPONSE ACTIONS LEGEND									
A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other									
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: East Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 5		HA NUMBER 6		HA NUMBER 7		HA NUMBER 8	
		CURRENT QUANTITY		CURRENT QUANTITY 11417 SF		CURRENT QUANTITY 10070 SF		CURRENT QUANTITY 1544 SF	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE TSI SURFACING MISCELLANEOUS	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	
	X	X	X	X	X	X	X	X	
CHECK ONE									
ASSUMED ACBM CONFIRMED ACBM NON-ACBM									
	X	X	X	X	X	X	X	X	
CHECK ONE									
NON-FRIABLE FRIABLE									
	X	X	X	X	X	X	X	X	
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION	1	1	1	1	1	1	1	1	
PHYSICAL DAMAGE	1	1	1	1	1	1	1	1	
WATER DAMAGE	1	1	1	1	1	1	1	1	
ACTIVITY/VIBRATION	2	2	2	2	2	2	2	2	
EXPOSURE	1	1	1	1	1	1	1	1	
ACCESSIBILITY	1	1	1	1	1	1	1	1	
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK									
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK	X	X	X	X	X	X	X	X	
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE	X	X	X	X	X	X	X	X	
CUSTODIAL	X	X	X	X	X	X	X	X	
FACULTY/STAFF	X	X	X	X	X	X	X	X	
PUBLIC	X	X	X	X	X	X	X	X	
ASSESSMENT									
(MARK FROM 1 TO 7)									
	5	5	5	5	5	5	5	5	
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
	B	B	B	B	B	B	B	B	
ASSESSMENT LEGEND					RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate				
					E. Enclosure F. Remove G. Isolate H. Other				
					NOTES				
					*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: East Chester Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

	HA NUMBER 9	HA NUMBER	HA NUMBER	HA NUMBER
	CURRENT QUANTITY 960 SF	CURRENT QUANTITY 52000 SF	CURRENT QUANTITY	CURRENT QUANTITY
	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION 2x4 Ceiling Tile	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI								
SURFACING								
MISCELLANEOUS	X	X	X	X				

CHECK ONE

ASSUMED ACBM			X	X				
CONFIRMED ACBM	X	X						
NON-ACBM								

CHECK ONE

NON-FRIABLE	X	X						
FRIABLE			X	X				

EXPOSURE CONSIDERATION
1 TO 5 (5 WORST)

DETERIORATION	1	1	1	1				
PHYSICAL DAMAGE	1	1	1	1				
WATER DAMAGE	1	1	1	1				
ACTIVITY/VIBRATION	2	2	1	1				
EXPOSURE	2	2	1	1				
ACCESSIBILITY	1	1	1	1				

LENGTH OF EXPOSURE
(CHECK ONE)

1 HOUR/WEEK			X	X				
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK	X	X						

EXPOSURE POPULATION
(CHECK ALL APPLICABLE)

MAINTENANCE	X	X	X	X				
CUSTODIAL	X	X	X	X				
FACULTY/STAFF	X	X	X	X				
PUBLIC	X	X	X	X				

ASSESSMENT
(MARK FROM 1 TO 7)

	5	5	7	7				
--	---	---	---	---	--	--	--	--

****RESPONSE ACTIONS**
(MARK FROM A TO H)

B	B	B	B				
---	---	---	---	--	--	--	--

ASSESSMENT LEGEND

1. Damaged/significantly damaged TSI
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing material
4. Damaged/significantly damaged friable misc. ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or suspect ACBM

RESPONSE ACTIONS LEGEND

A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate	E. Enclosure F. Remove G. Isolate H. Other
---------------------------------------------------------------------------------------	-----------------------------------------------------


NOTES


*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0

** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5

Christopher R. Johnson
INSPECTOR (Typed Name)

Christopher R. Johnson
MANAGEMENT PLANNER


SIGNATURE


SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Jacks Creek Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 1		HA NUMBER 2		HA NUMBER 3		HA NUMBER 4	
		CURRENT QUANTITY 6401 SF		CURRENT QUANTITY 42 SF		CURRENT QUANTITY 959 SF		CURRENT QUANTITY 1512 SF	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	
TSI		X	X	X	X	X	X	X	
SURFACING									
MISCELLANEOUS									
CHECK ONE									
ASSUMED ACBM									
CONFIRMED ACBM		X	X	X	X	X	X	X	
NON-ACBM									
CHECK ONE									
NON-FRIABLE		X	X	X	X	X	X		
FRIABLE								X	
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION		1	1	1	1	1	1	1	
PHYSICAL DAMAGE		1	1	1	1	1	1	1	
WATER DAMAGE		1	1	1	1	1	1	1	
ACTIVITY/VIBRATION		2	2	2	2	2	2	2	
EXPOSURE		1	1	1	1	1	1	1	
ACCESSIBILITY		1	1	1	1	1	1	1	
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK									
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK		X	X	X	X	X	X	X	
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE		X	X	X	X	X	X	X	
CUSTODIAL		X	X	X	X	X	X	X	
FACULTY/STAFF		X	X	X	X	X	X	X	
PUBLIC		X	X	X	X	X	X	X	
ASSESSMENT									
(MARK FROM 1 TO 7)									
		5	5	5	5	5	5	5	
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
		B	B	B	B	B	B	B	
ASSESSMENT LEGEND									
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					RESPONSE ACTIONS LEGEND A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Jacks Creek Elementary School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

	HA NUMBER	HA NUMBER	HA NUMBER	HA NUMBER
	CURRENT QUANTITY 15000 SF	CURRENT QUANTITY	CURRENT QUANTITY	CURRENT QUANTITY
	MATERIAL DESCRIPTION 2X4 Ceiling Tile	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION
CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI				
SURFACING				
MISCELLANEOUS	X	X		
CHECK ONE				
ASSUMED ACBM	X	X		
CONFIRMED ACBM				
NON-ACBM				
CHECK ONE				
NON-FRIABLE				
FRIABLE	X	X		
EXPOSURE CONSIDERATION				
1 TO 5 (5 WORST)				
DETERIORATION	1	1		
PHYSICAL DAMAGE	1	1		
WATER DAMAGE	1	1		
ACTIVITY/VIBRATION	1	1		
EXPOSURE	1	1		
ACCESSIBILITY	1	1		
LENGTH OF EXPOSURE				
(CHECK ONE)				
1 HOUR/WEEK	X	X		
5 HOUR/WEEK				
10 HOUR/WEEK				
20 HOUR/WEEK				
40 HOUR/WEEK				
EXPOSURE POPULATION				
(CHECK ALL APPLICABLE)				
MAINTENANCE	X	X		
CUSTODIAL	X	X		
FACULTY/STAFF				
PUBLIC				
ASSESSMENT				
(MARK FROM 1 TO 7)				
	7	7		
**RESPONSE ACTIONS				
(MARK FROM A TO H)				
	B	B		
ASSESSMENT LEGEND				
RESPONSE ACTIONS LEGEND				
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM		A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other		
NOTES				
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5				

Christopher R. Johnson
INSPECTOR (Typed Name)

Christopher R. Johnson
SIGNATURE

Christopher R. Johnson
SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

A-MP-42505-44824/TN
ACCREDITATION #/STATE



THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Jr. High School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

		HA NUMBER 1		HA NUMBER 2		HA NUMBER 4		HA NUMBER 5	
		CURRENT QUANTITY 1800 SF		CURRENT QUANTITY 212 SF		CURRENT QUANTITY 3066 SF		CURRENT QUANTITY 5124 SF	
		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile		MATERIAL DESCRIPTION Floor Tile	
CHECK ONE	LAST 3 YEAR								
	CURRENT								
TSI									
SURFACING									
MISCELLANEOUS		X	X	X	X	X	X	X	X
CHECK ONE									
ASSUMED ACBM		X	X	X	X	X	X	X	X
CONFIRMED ACBM									
NON-ACBM									
CHECK ONE									
NON-FRIABLE		X	X	X	X	X	X	X	X
FRIABLE									
EXPOSURE CONSIDERATION									
1 TO 5 (5 WORST)									
DETERIORATION		1	1	1	1	1	1	1	1
PHYSICAL DAMAGE		1	1	1	1	1	1	1	1
WATER DAMAGE		1	1	1	1	1	1	1	1
ACTIVITY/VIBRATION		2	2	2	2	2	2	2	2
EXPOSURE		1	1	1	1	1	1	1	1
ACCESSIBILITY		1	1	1	1	1	1	1	1
LENGTH OF EXPOSURE									
(CHECK ONE)									
1 HOUR/WEEK									
5 HOUR/WEEK									
10 HOUR/WEEK									
20 HOUR/WEEK									
40 HOUR/WEEK		X	X	X	X	X	X	X	X
EXPOSURE POPULATION									
(CHECK ALL APPLICABLE)									
MAINTENANCE		X	X	X	X	X	X	X	X
CUSTODIAL		X	X	X	X	X	X	X	X
FACULTY/STAFF		X	X	X	X	X	X	X	X
PUBLIC		X	X	X	X	X	X	X	X
ASSESSMENT									
(MARK FROM 1 TO 7)									
		5	5	5	5	5	5	5	5
**RESPONSE ACTIONS									
(MARK FROM A TO H)									
		B	B	B	B	B	B	B	B
ASSESSMENT LEGEND									
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM					RESPONSE ACTIONS LEGEND A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other				
NOTES									
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5									

Christopher R. Johnson INSPECTOR (Typed Name)	 SIGNATURE	A-I-42505-44826/TN ACCREDITATION #/STATE
Christopher R. Johnson MANAGEMENT PLANNER	 SIGNATURE	A-MP-42505-44824/TN ACCREDITATION #/STATE

THREE YEAR REINSPECTION

LEA NAME: Chester County Schools LEA #: 120

School Building Name: Chester County Jr. High School Building #: Main

DATE OF IMPLEMENTATION OF MANAGEMENT PLAN: 7/9/89 INSPECTION DATE: 2/23/16

	HA NUMBER 7	HA NUMBER	HA NUMBER	HA NUMBER
	CURRENT QUANTITY 164 SF	CURRENT QUANTITY 70000 SF	CURRENT QUANTITY	CURRENT QUANTITY
	MATERIAL DESCRIPTION Floor Tile	MATERIAL DESCRIPTION 2x4 Ceiling Tile	MATERIAL DESCRIPTION	MATERIAL DESCRIPTION

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
TSI								
SURFACING								
MISCELLANEOUS	X	X	X	X				

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
ASSUMED ACBM	X	X	X	X				
CONFIRMED ACBM								
NON-ACBM								

CHECK ONE	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT	LAST 3 YEAR	CURRENT
NON-FRIABLE	X	X						
FRIABLE			X	X				

EXPOSURE CONSIDERATION								
1 TO 5 (5 WORST)								
DETERIORATION	1	1	1	1				
PHYSICAL DAMAGE	1	1	1	1				
WATER DAMAGE	1	1	1	1				
ACTIVITY/VIBRATION	2	2	2	2				
EXPOSURE	1	1	1	1				
ACCESSIBILITY	1	1	1	1				

LENGTH OF EXPOSURE								
(CHECK ONE)								
1 HOUR/WEEK			X	X				
5 HOUR/WEEK								
10 HOUR/WEEK								
20 HOUR/WEEK								
40 HOUR/WEEK	X	X						

EXPOSURE POPULATION								
(CHECK ALL APPLICABLE)								
MAINTENANCE	X	X	X	X				
CUSTODIAL	X	X	X	X				
FACULTY/STAFF	X	X						
PUBLIC	X	X						

ASSESSMENT								
(MARK FROM 1 TO 7)								
	5	5	7	7				

**RESPONSE ACTIONS								
(MARK FROM A TO H)								
	B	B	B	B				

ASSESSMENT LEGEND	RESPONSE ACTIONS LEGEND
1. Damaged/significantly damaged TSI 2. Damaged friable surfacing ACBM 3. Significantly damaged friable surfacing material 4. Damaged/significantly damaged friable misc. ACBM 5. ACBM with potential for damage 6. ACBM with potential for significant damage 7. Any remaining friable ACBM or suspect ACBM	A. Institute preventative measures B. O & M Program C. Repair D. Encapsulate E. Enclosure F. Remove G. Isolate H. Other

NOTES	
*If previously assumed ACBM was tested, attach TAHERA 6.2, TAHERA 6.3, TAHERA 6.9 and TAHERA 8.0 ** If "current" is different from "last 3 year", attach revised TAHERA 6.4 and TAHERA 6.5	

Christopher R. Johnson
INSPECTOR (Typed Name)

SIGNATURE

A-I-42505-44826/TN
ACCREDITATION #/STATE

Christopher R. Johnson
MANAGEMENT PLANNER

SIGNATURE

A-MP-42505-44824/TN
ACCREDITATION #/STATE



THE STATE OF TENNESSEE

Department of Environment and Conservation Division of Solid Waste Management
Toxic Substances Program

William R. Snodgrass Tennessee Tower
312 Rosa L. Parks Avenue, 14th Floor Nashville TN 37243

By virtue of the authority vested by the Division of Solid Waste Management, the
Company named below is hereby accredited to offer and/or conduct Asbestos activities
pursuant to Rule 1200-01-20:

Resolution Incorporated

1101-A Darbytown Dr. Nashville TN, 37207

to conduct ASBESTOS ACTIVITIES in schools or public and commercial buildings in Tennessee.
This firm is responsible for compliance with the applicable requirements of Rule 1200-01-20.

Discipline	Type	Accreditation Number	Effective Date	Expiration Date
Accreditation	Re-Accreditation	A-F-690-46059	December 01, 2015	December 31, 2016



Given under the Seal of the State of Tennessee in Nashville.

This 18th Day of December 2015

Division of Solid Waste Management
Toxic Substance Program

CN-1324 (Rev 6/13)

RDA-3020

THE STATE OF TENNESSEE

Department of Environment and Conservation
Division of Solid Waste Management
Toxic Substances Program



Christopher R. Johnson

DOB 30-Nov-1961 Sex M HGT 5' 9" WGT 185

Discipline	Accreditation	Expiration
Inspector	A-I-42505-44826	Oct-31-2016
Management Planner	A-MP-42505-44824	Oct-31-2016
Project Designer	A-PD-42505-44825	Oct-31-2016
Project Monitor	A-PM-42505-44823	Oct-31-2016

Asbestos Accreditation

Re-Accreditation

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print). Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: [Signature]
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date 8/22/2016 (Fall)	2nd six months Date 2/9/2017 (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	Good	
2	Floor tile	All	Good	Good	
3	Floor tile	All	Good	Good	
4	Floor tile	All	Good	Good	
	2x4 Ceiling tile	All	Good	Good	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

EA NAME: CHESTER COUNTY BOE

LEA NO: 120SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the EHA, Description of ACBM, and Area Inspected. If the ACBM has been removed, put the date removed in the appropriate column. Keep the original with your Management Plan.

[illegible]

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: Bm
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>8/9/2017</u> (Fall)	2nd six months Date <u>2/8/2017</u> (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	Good	
2	Floor tile	All	Good	Good	
3	Floor tile	All	Good	Good	
4	Floor tile	All	Good	Good	
	2x4 Ceiling tile	All	Good	Good	

*IF NO CHANGE IN CONDITION WRITE "N.C."

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

TAHERA 9.0 (2/97)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>8/6/2018</u> (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good		
2	Floor tile	All	Good		
3	Floor tile	All	Good		
4	Floor tile	All	Good		
	2x4 Ceiling tile	All	Good		

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

AHERA 9.0 (2/97)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025

BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. **Keep** the original with **your** Management Plan.

[illegible]

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: _____
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

THERA 9.0 (2/97)

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date 8/8/2018 (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	Good	
2	Floor tile	All	Good	Good	
3	Floor tile	All	Good	Good	
4	Floor tile	All	Good	Good	
	2x4 Ceiling tile	All	Good	Good	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

TAHERA 9.0 (2/97)



January 21, 2020

Mr. Britt Eads
Chester County Schools
970 East Main Street
Henderson, Tennessee 38340
Eadsb01@120cc.org
(731) 433-7266

**RE: PCM CLEARANCE RESULTS
65 TN-22 ALTERNATE
JACKS CREEK, TENNESSEE 38347
PROJECT NO. 159719**

Mr. Eads:

Resolution, Inc. has completed the asbestos air testing regarding the above referenced project. All testing was performed by Mr. Dominic Motes an Asbestos Hazard Emergency Response Act (AHERA) and State of Tennessee accredited project monitor.

A total of nine (9) air samples were collected from one (1) regulated work areas. Samples were collected using pre-calibrated high-volume pumps according to EPA and NIOSH air sampling protocols. All samples were analyzed using Phase Contrast Microscopy (PCM) according to the National Institute for Occupational Safety and Health (NIOSH) Method 7400. The following table is a summary of the analytical results.

SUMMARY OF AHERA PCM CLEARANCE RESULTS

Sample No.	Sample Type	Sample Location	Volume (L)	Result (f/cc)	Pass/Fail
1	In Area	In Kitchen, ADJ to doorway	300	0.0065	Pass
2	In Area	In Kitchen, ADJ to sink	300	0.0049	Pass
3	Outside Area	In Kitchen, ADJ to fridge	300	0.0033	Pass
4	Clearance	North Wall in containment	1260	0.0023	Pass
5	Clearance	South Wall in containment	1260	0.0027	Pass
6	Clearance	East Wall in containment	1260	0.0027	Pass
7	Clearance	West Wall containment	1260	0.0031	Pass
8	Clearance	Center of Containment	1260	0.0023	Pass
9	Clearance	Field Blank	0	0.0065	Pass

From the analytical, all clearance results are below the AHERA PCM clearance level of <0.01 fibers per cubic centimeter (f/cc). The work areas are cleared for re-occupancy.

Should you have any questions or require additional information, please feel free to call my office at (615) 865-8813 or my cell at (410) 725-2302.

Sincerely,

RESOLUTION, INC.

Dominic Motes, Field Technician Hygienist.

Attn: Analytical Report Sheets
Accreditations

Resolution, Inc.
1101A Darbytown Drive
Nashville, Tennessee 37207
Phone (615) 865-8813 Fax (615) 868-4140
www.resolutionusa.com

RESOLUTION, INCORPORATED

ENVIRONMENTAL CONSULTANTS

1101 A DARBYTOWN DRIVE NASHVILLE, TN 37207 (615) 865-8813 FAX (615) 868-4140

ASBESTOS SAMPLE COLLECTION DATA SHEET

PROJECT NUMBER: 159719

PROJECT LOCATION: 907 Hatcher Lane, Columbia Tennessee 38401

PROJECT DATE: 1/20/2020

CONTRACTOR: ESI

REMOVAL ACTIVITY: Floortile and mastic

ANALYTICAL METHOD: NIOSH 7400 - "A" COUNTING RULE

TECHNICIAN: Dominic Motes

SUPERVISOR: Josh Goodman

SAMPLE ID	SAMPLE TYPE	LOCATION / NAME & SOCIAL SECURITY NUMBER	JOB TASK	RESP PROT	TIME ON	TIME OFF	TOTAL TIME	LPM	VOLUME (LITER)
1	IA	In Kitchen, ADJ to doorway			9:30	10:30	60	5	300
2	IA	In Kitchen, ADJ to sink			9:30	10:30	60	5	300
3	OA	In Kitchen, ADJ to fridge			9:30	10:30	60	5	300
4	CL	North Wall in containment			10:35	11:45	70	18	126
5	CL	South Wall in containment			10:35	11:45	70	18	126
6	CL	East Wall in containment			10:35	11:45	70	18	126
7	CL	West Wall containment			10:35	11:45	70	18	126
8	CL	Center of Containment			10:35	11:45	70	18	126
9	FB	Field Blank							

REMARKS:

SAMPLE TYPE: AM - Ambient; CL - Clearance; EXC - Excursion; IA - Inside Area; OA - Outside Area; PR - Personnel
RESPIRATORY PROTECTION: 1/2 - Half-Face; FULL - Full Face; PAPR - Powered Air Purifying Respirator

QA/QC CODE:

THE STATE OF TENNESSEE

Department of Environment and Conservation
Division of Solid Waste Management
Toxic Substances Program



Initial

Dominic A Motes

DOB	Sex	HGT	WGT
31-Jul-1985	M	5' 7"	150

Discipline	Accreditation	Expiration
Inspector	A-I-122940-75588	Mar-31-2020
Project Monitor	A-PM-122940-75588	Mar-31-2020

Asbestos Accreditation



THE STATE OF TENNESSEE

Department of Environment and Conservation Division of Solid Waste Management
Toxic Substances Program

William R. Snodgrass Tennessee Tower
312 Rosa L. Parks Avenue, 14th Floor Nashville TN 37243

By virtue of the authority vested by the Division of Solid Waste Management, the
Company named below is hereby accredited to offer and/or conduct Asbestos activities
pursuant to Rule 1200-01-20:

Resolution Incorporated

1101-A Darbytown Dr Nashville TN, 37207

to conduct ASBESTOS ACTIVITIES in schools or public and commercial buildings in Tennessee.
This firm is responsible for compliance with the applicable requirements of Rule 1200-01-20.

Discipline	Type	Accreditation Number	Effective Date	Expiration Date
Accreditation	Re-Accreditation	A-F-690-82185	November 06, 2019	December 31, 2020



Given under the Seal of the State of Tennessee in Nashville.

This 6th Day of November 2019

Division of Solid Waste Management
Toxic Substance Program

CN-1324 (Rev 6/13)

RDA-3020

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date 8/8/2018 (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good	Good	
2	Floor tile	All	Good	Good	
3	Floor tile	All	Good	Good	
4	Floor tile	All	Good	Good	
	2x4 Ceiling tile	All	Good	Good	

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

PERIODIC SURVEILLANCE REPORT

LEA NAME: CHESTER COUNTY BOE

LEA NO: 120

SCHOOL NAME: JACKS CREEK ELEMENTARY

SCHOOL NO.: 120-0025


BUILDING NAME: MAIN

INSTRUCTIONS: AHERA regulations require a Periodic Surveillance be conducted every six (6) months. Each School building containing ACBM must be inspected. Put the date in the appropriate column. Fill in the HA#, Description of ACBM, and Area Inspected. If the ACBM has been removed put the date removed in the appropriate column. Keep the original with your Management Plan.

			1st six months Date <u>8/4/2020</u> (Fall)	2nd six months Date (Spring)	
HA#	DESCRIPTION OF ACBM	AREA INSPECTED	ACBM CONDITION*	ACBM CONDITION*	DATE REMOVED
1	Floor tile	All	Good		
2	Floor tile	All	Good		
3	Floor tile	All	Good		
4	Floor tile	All	Good		
	2x4 Ceiling tile	All	Good		

*IF NO CHANGE IN CONDITION WRITE N/C

SURVEILLANCE INSPECTOR'S NAME (please print): Britt Eads

SURVEILLANCE INSPECTOR'S SIGNATURE: 
(Surveillance Inspector is not required to be AHERA certified)

AHERA Accreditation Number/Date (if applicable): _____

TAHERA 9.0 (2/97)