



Box R Water Analysis Laboratory

567 NW Second Street
Prineville, Oregon 97754
541-447-4911

Mr. Wade Peasley

Aug 22, 2016

c/o Harney County School District #3

550 North Court Ave.

Burns, OR 97720

Sample Nbr: X023293


Dear Mr. Peasley,

Attached is a copy of your drinking water – Lead – test results, sampled on Aug 5, 2016, at Slater School, Burns, OR. Your analysis was performed by Neilson Research Corp. in Medford, OR. Please do not hesitate to call Box R Water Analysis Laboratory with any questions you may have in regards to your water testing.

Thank you for using Box R Water Analysis Laboratory, we appreciate your business.

Sincerely,

Sherri K. Miyazaki – Box R Water Analysis Laboratory Director



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

8/22/2016

Sherri Miyazaki
Box R Waterlab
567 NW Second Street
Prineville, OR 97754

TEL: (541) 447-4911
FAX (541) 447-4917

RE: X023293 Slater School

Order No.: 1608489

Dear Sherri Miyazaki:

Neilson Research Corporation received 10 sample(s) on 8/9/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X023293 Slater School
Lab Order: 1608489

Date: 22-Aug-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608489
NRC Sample ID: 1608489-01A
Collection Date: 8/5/2016 6:45:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/22/2016 3:50:19 PM

Sample Information:

X023293 Slater School

Client Sample ID: X023293-01
Collectors Name: Wade Peasley
Sample Location: Kitchen
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP			Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result						
Lead	EPA 200.8	A	0.00334		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-02A**
Collection Date: **8/5/2016 6:50:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-02
Collectors Name: Wade Peasley
Sample Location: DF by Office
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000294		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608489
NRC Sample ID: 1608489-03A
Collection Date: 8/5/2016 6:56:00 AM
Received Date: 8/9/2016 10:06:00 AM
Reported Date: 8/22/2016 3:50:19 PM

Sample Information:

X023293 Slater School

Client Sample ID: X023293-03
Collectors Name: Wade Peasley
Sample Location: DF by B & G RR
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP		Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited							
Lead	EPA 200.8	A	0.000318		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-04A**
Collection Date: **8/5/2016 6:57:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-04
Collectors Name: Wade Peasley
Sample Location: DF N West Hall
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-05A**
Collection Date: **8/5/2016 6:58:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-05
Collectors Name: Wade Peasley
Sample Location: DF End of Hall
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000198		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-06A**
Collection Date: **8/5/2016 6:55:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-06
Collectors Name: Wade Peasley
Sample Location: Staff Room
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00212		0.000103	mg/L	0.020 AL	8/11/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-07A**
Collection Date: **8/5/2016 7:08:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-07
Collectors Name: Wade Peasley
Sample Location: Unit (2) DF by #28
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00172		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-08A**
Collection Date: **8/5/2016 7:00:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-08
Collectors Name: Wade Peasley
Sample Location: Faucet by #26
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00131		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-09A**
Collection Date: **8/5/2016 7:10:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-09
Collectors Name: Wade Peasley
Sample Location: Faucet by Gym
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000212		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608489**
NRC Sample ID: **1608489-10A**
Collection Date: **8/5/2016 7:11:00 AM**
Received Date: **8/9/2016 10:06:00 AM**
Reported Date: **8/22/2016 3:50:19 PM**

Sample Information:

X023293 Slater School

Client Sample ID: X023293-10
Collectors Name: Wade Peasley
Sample Location: Gym
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000378		0.000103	mg/L	0.020 AL	8/14/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

CLIENT: Box R Waterlab
 Work Order: 1608489
 Project: X023293 Slater School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-36193	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89157					
Client ID:	ZZZZZ	Batch ID: 36193	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/11/2016	SeqNo: 1343259					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	MB-36194	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89203					
Client ID:	ZZZZZ	Batch ID: 36194	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/14/2016	SeqNo: 1344993					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	LCS-36193	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89157					
Client ID:	ZZZZZ	Batch ID: 36193	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/11/2016	SeqNo: 1343260					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09309 0.000104 0.1 0.0000234 93.1 85 115

Sample ID	LCS-36194	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89203					
Client ID:	ZZZZZ	Batch ID: 36194	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/14/2016	SeqNo: 1344994					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09541 0.000104 0.1 0 95.4 85 115

Sample ID	1608489-06AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89157					
Client ID:	X023293-06	Batch ID: 36193	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/11/2016	SeqNo: 1343283					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09707 0.000104 0.1 0.002125 94.9 70 130

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Box R Waterlab
 Work Order: 1608489
 Project: X023293 Slater School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID 1608517-12AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89203						
Client ID: ZZZZZ	Batch ID: 36194	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/14/2016	SeqNo: 1345013						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.09718	0.000104	0.1	0.002817	94.4	70	130				

Sample ID 1608489-06AMS	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89157						
Client ID: X023293-06	Batch ID: 36193	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/11/2016	SeqNo: 1343284						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.09692	0.000104	0.1	0.002125	94.8	70	130	0.09707	0.161	20	

Sample ID 1608517-12AMS	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/10/2016	RunNo: 89203						
Client ID: ZZZZZ	Batch ID: 36194	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/14/2016	SeqNo: 1345014						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.09728	0.000104	0.1	0.002817	94.5	70	130	0.09718	0.107	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: **Box R Water Analysis Laboratory**
 Address: **567 NW Second St. Prineville, Or 97754**
 Email: **PRC**
 Phone: **PRC**
 Collected By (Print): **Wade Peasley**
 Collected By (Sign): **Wade Peasley**
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
Required Project Information

Project Name: **Harney County School District #3**
 Project Number: **X023293 (1-10)**
 Report To: **SK Miyazaki**
 Copy To: **Wade Peasley**

Section C
Invoice Information

Company Name: **Howard Peasley**
 Address: **550 N. Court Ave Burns OR 97701**
 P.O. # **N/A**

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
Sample Information

(Slater School)

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
X023293 (19760)	Grab	DF	080516	0645	1	X
(19752)				0650	1	X
(19795)				0656	1	X
(19800)				0657	1	X
(19786)				0658	1	X
(19778)				0655	1	X
(19762)				0708	1	X
(19780)				0700	1	X
(19766)				0710	1	X
(19805)				0711	1	X

1608489

Remarks/Field Data
Kitchen
DF by Office
DF by B. G. Lopez
DF N. West Hall
DF End of Hall
Staff Room
Dist (2) DF by B. G. Lopez
Faucet by 3/4
Faucet by Gym
Sum

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: [Signature]		Shem Miyazaki	080516	1330
Received By:				
Relinquished By:				
Received By:				
Relinquished By: [Signature]		S. Murray	8/9/16	10:00
Received By Laboratory:				

Section G
Lab Use Only

10 B/W

Field Blank Included: Yes No

Received Via: UPS FedEx Other Hand

Card: VISA M/C Check # _____ Amount _____