



1145 Delsea Drive  
Westville, NJ 08093  
Tel: 856.848.4700  
www.adsschool.org

# ARCHBISHOP DAMIANO SCHOOL

*Making a difference in the lives of our students*

October 19, 2020

Re: Lead Analysis Review

An initial lead analysis for all taps across the St. John of God Community Services (SJOGCS) and Archbishop Damiano School (ADS) campus was initially completed on March 1<sup>st</sup>, 2020. Every sink and water fountain on campus was tested through the collection of a first draw sample from an authorized technician from South Jersey Water Test. Prior to collection, all taps were closed for a minimum of 8 hours.

In all, 65 faucets were tested in Building A, 59 in Building B, and 25 in Building C. Of the aggregate of 149 total tests, 13 faucets showed levels of lead above the actionable level of 15.5ppm, 7 in Building A, 3 in Building B, and 3 in Building C. During the Covid-19 related closure of the facility, steps to remediate the high tests were taken. All faucets that tested high for actionable levels were replaced with the exception of one bathroom in Building C, in what was formerly known as the Monastery.

On October 7<sup>th</sup>, 2020 a retest of the lead positive faucets were retested and all fell under actionable levels with the exception of the faucet in the Monastery (Building C) that was not replaced. This sink has been removed entirely. It should be noted that the Monastery of Building C has not been in use for two years. There are currently no residents of this area of the building and no employees are permitted access with the exception of members of the facilities management team.

As of this time, all areas of the campus where students, consumers, and staff receive and deliver services have all tested below the actionable level of 15.5ppm of lead.

A handwritten signature in black ink, appearing to read 'Jason Bintliff', is located on the left side of the page.

Jason Bintliff  
Risk Manager, Compliance Officer

*Interim Director Kate Flynn • Principal Michele McCloskey*

*An affiliate program of St. John of God Community Services.*



*Hospitality • Quality • Respect • Spirituality • Responsibility*