

EXECUTIVE SUMMARY:

The YCS-Sawtelle Learning Center requested lead in water testing of potable water outlets at YCS-Sawtelle Learning Center, 208 South Mountain Avenue, Montclair, NJ 07042.

Previous Testing

No information related to previous testing was available.

Recent Testing (9/9/17)

In order to assess the building water outlets a full testing of all potable outlets was performed on September 9, 2017.

Reportedly the outlets were not flushed or used on the day of testing.

First draw samples were collected of 20 water fountains and sinks.

All results were below the Lead and Copper action level of 15 ppb.

See Section 3 Discussion of Results