



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-01	Sample Name: 01-005-KF-P Sampled: 2/15/21 9:10		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-02	Sample Name: 01-005-KF-F Sampled: 2/15/21 9:13		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-03	Sample Name: 02-005-KF-P Sampled: 2/15/21 9:14		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-04	Sample Name: 02-005-KF-F Sampled: 2/15/21 9:16		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-05	Sample Name: 03-005-KF-P Sampled: 2/15/21 9:19		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-06	Sample Name: 03-005-KF-F Sampled: 2/15/21 9:22		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-07	Sample Name: 04-005-KF-P Sampled: 2/15/21 9:23		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-08	Sample Name: 04-005-KF-F Sampled: 2/15/21 9:26		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-09	Sample Name: 07-005-KF-P Sampled: 2/15/21 9:27		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-10	Sample Name: 07-005-KF-F Sampled: 2/15/21 9:29		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-11	Sample Name: 05-005-WF-P Sampled: 2/15/21 9:35		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-12	Sample Name: 05-005-WF-F Sampled: 2/15/21 9:38		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-13	Sample Name: 06-005-WF-P Sampled: 2/15/21 9:39		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-14	Sample Name: 06-005-WF-F Sampled: 2/15/21 9:43		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-15	Sample Name: 08-005-KF-P Sampled: 2/15/21 9:43		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-16	Sample Name: 08-005-KF-F Sampled: 2/15/21 9:45		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-17	Sample Name: 09-005-KF-P Sampled: 2/15/21 9:48		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-18	Sample Name: 09-005-KF-F Sampled: 2/15/21 9:50		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-19	Sample Name: 11-005-KF-P Sampled: 2/15/21 9:51		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-20	Sample Name: 11-005-KF-F Sampled: 2/15/21 9:54		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-21	Sample Name: 10-005-KF-P Sampled: 2/15/21 9:57		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	4	ppb	2	15 ppb	02/19/21 14:15
1049021-22	Sample Name: 10-005-KF-F Sampled: 2/15/21 10:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-23	Sample Name: 12-005-KF-P Sampled: 2/15/21 10:04		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-24	Sample Name: 12-005-KF-F Sampled: 2/15/21 10:07		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-25	Sample Name: 13-005-KF-P Sampled: 2/15/21 10:08		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-26	Sample Name: 13-005-KF-F Sampled: 2/15/21 10:10		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-27	Sample Name: 14-005-WF-P Sampled: 2/15/21 10:11		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-28	Sample Name: 14-005-WF-F Sampled: 2/15/21 10:15		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-29	Sample Name: 15-007-WF-P Sampled: 2/15/21 11:02		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-30	Sample Name: 15-007-WF-F Sampled: 2/15/21 11:05		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-31	Sample Name: 16-007-KF-P Sampled: 2/15/21 11:05		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-32	Sample Name: 16-007-KF-F Sampled: 2/15/21 11:07		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-33	Sample Name: 17-007-WF-P Sampled: 2/15/21 11:07		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-34	Sample Name: 17-007-WF-F Sampled: 2/15/21 11:10		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-35	Sample Name: 18-007-KF-P Sampled: 2/15/21 11:11		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-36	Sample Name: 18-007-KF-F Sampled: 2/15/21 11:14		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-37	Sample Name: 19-007-KF-P Sampled: 2/15/21 11:14		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-38	Sample Name: 19-007-KF-F Sampled: 2/15/21 11:17		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-39	Sample Name: 20-007-FS-P Sampled: 2/15/21 11:19		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-40	Sample Name: 20-007-FS-F Sampled: 2/15/21 11:22		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-41	Sample Name: 21-007-WF-P Sampled: 2/15/21 11:24		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-42	Sample Name: 21-007-WF-F Sampled: 2/15/21 11:27		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-43	Sample Name: 22-007-KF-P Sampled: 2/15/21 11:28		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-44	Sample Name: 22-007-KF-F Sampled: 2/15/21 11:32		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-45	Sample Name: 23-007-WF-P Sampled: 2/15/21 11:34		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-46	Sample Name: 23-007-WF-F Sampled: 2/15/21 11:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-47	Sample Name: 24-007-KF-P Sampled: 2/15/21 11:39		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-48	Sample Name: 24-007-KF-F Sampled: 2/15/21 11:41		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-49	Sample Name: 25-007-WF-P Sampled: 2/15/21 11:42		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-50	Sample Name: 25-007-WF-F Sampled: 2/15/21 11:45		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-51	Sample Name: 26-007-WF-P Sampled: 2/15/21 11:46		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-52	Sample Name: 26-007-WF-F Sampled: 2/15/21 11:49		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-53	Sample Name: 27-007-KF-P Sampled: 2/15/21 11:49		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-54	Sample Name: 27-007-KF-F Sampled: 2/15/21 11:51		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-55	Sample Name: 28-007-KF-P Sampled: 2/15/21 11:52		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-56	Sample Name: 28-007-KF-F Sampled: 2/15/21 11:55		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-57	Sample Name: 29-007-WF-P Sampled: 2/15/21 11:56		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-58	Sample Name: 29-007-WF-F Sampled: 2/15/21 11:59		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-59	Sample Name: 30-007-WF-P Sampled: 2/15/21 12:02		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-60	Sample Name: 30-007-WF-F Sampled: 2/15/21 12:06		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/26/2021
Received: 02/18/2021
Sampled By:
Work Order: 1049021

C Seaside School District
L Attn: Chuck Loesch
I 2600 Spruce Drive, Suite 100
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1049021-61	Sample Name: 31-007-WF-P Sampled: 2/15/21 12:07		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-62	Sample Name: 31-007-WF-F Sampled: 2/15/21 12:10		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-63	Sample Name: 32-007-KF-P Sampled: 2/15/21 12:11		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-64	Sample Name: 32-007-KF-F Sampled: 2/15/21 12:15		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-65	Sample Name: 33-007-KF-P Sampled: 2/15/21 12:17		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-66	Sample Name: 33-007-KF-F Sampled: 2/15/21 12:19		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-67	Sample Name: 34-007-KF-P Sampled: 2/15/21 12:24		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15
1049021-68	Sample Name: 34-007-KF-F Sampled: 2/15/21 12:27		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	02/19/21 14:15

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director