

Water Testing Results - Slater Elementary
Action Level is 20 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen		8/5/2016	3.34
Drinking Fountain by Office		8/5/2016	0.294
Drinking Fountain by Boy's & Girl's Restrooms		8/5/2016	0.318
Drinking Fountain NW Hall		8/5/2016	ND
Drinking Fountain End of Hall		8/5/2016	0.198
Staff Room		8/5/2016	2.12
Unit 2 Drinking Fountain by #28		8/5/2016	1.72
Faucet by #26		8/5/2016	1.31
Faucet by Gym		8/5/2016	0.212
Gym		8/5/2016	0.378

ND = Non Detect - Lead level is below the set detection limits of 0.103 ppb

Lab Sheets reporting in mg/L - Convert mg/L to ppb by Multiplying by 1,000