



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #100036

**Paulsboro Board of Education
District Administration Building**

662 North Delaware Street
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 06/10/2017 09:30 - 09:36

Date & Time Analyzed: 06/18/2017 19:29 - 20:02

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
AB-DW-01	178	15.5
AB-DW-02	<2.00	15.5
AB-DW-03	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Paulsboro Board of Education District Administration Building

662 North Delaware Street
Paulsboro, NJ 08066

Results of Lead Analysis

Date & Time Sampled: 07/10/2017 08:05

Date & Time Analyzed: 07/10/2017 23:19

Sample Location	Sample Result
AB-DW-01 (Flushed)	7.12

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action is required.
QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 10% of the target value.
Field Reagent Blank (FRB) concentration equals <2.0 ug/L



Mark J. Riether, Laboratory Director