

Pittsburg School

Test Results for Lead in the Water

	Test Location	Sample Date	Lab Report Date	Stagnant Lead, (mg/L)
	Basement - PE Office Sink	4/15/2019	4/19/2019	0.0014
	Basement - Consumer Science Sink	4/15/2019	4/19/2019	ND
	2nd Floor Rm 203 Bathroom Sink	4/15/2019	4/19/2019	ND
	2nd Floor Custodian Closet Sink	4/15/2019	4/19/2019	ND
	2nd Floor Girls Bathroom Sink #1	4/15/2019	4/19/2019	0.0026
	2nd Floor Girls Bathroom Sink #3	4/15/2019	4/19/2019	0.0026
	2nd Floor Drinking Fountain #1	4/15/2019	4/19/2019	ND
	Library Office Sink #1	4/15/2019	4/19/2019	0.0096
	Kitchen Sink #3	4/15/2019	4/19/2019	0.0066
	Custodian Closet Sink	4/15/2019	4/19/2019	ND
	Elementary Wing Girls Bathroom Sink #1	4/15/2019	4/19/2019	ND
	Elementary Wing Girls Bathroom Sink #2	4/15/2019	4/19/2019	0.0037
	Deep Sink	4/15/2019	4/19/2019	ND

Bolded data indicates elevated lead levels. ND = None Detected