

Seaside School District 10

Lead Testing Results in a Water Analysis Report 7/14/2017

Results for lead testing in water are provided in an *Analysis Report* from Alexin Analytical ORELAP Accredited Lab# OR-100013. Use the information below to determine from which location each sample was taken, as well as the type of sample taken.

Location Number: This number designates the site from which the sample was taken (GES=004 Gearhart Elementary, SHE=005 Seaside Heights Elementary, BMS=006 Broadway Middle School, SHS=007 Seaside High School).

Sample Number and Collection Site:

1 GES S Hall Fountain	14 BMS Gym 2 Fountain	27 SHE Kitchen Dish Faucet
2 GES N Hall Fountain	15 SHS Kitchen Faucet South	28 SHE Staff Rm Faucet
3 GES Rm 9 Fountain	16 SHS Kitchen Faucet East	29 SHE Rm C6 Fountain
4 GES Rm 7 Fountain	17 SHS Hall Rm 15 Fountain	30 SHE W Hall Fountain
5 GES Rm 6 Fountain	18 SHS Hall Rm 6 Fountain	31 SHE Rm B4 Fountain
6 GES Kitchen E Faucet	19 SHS Rm 5 SE Faucet	32 SHE Rm A3 Fountain
7 GES Boiler Rm Flush	20 SHS Hall Rm 1 Fountain	33 SHE E Hall Fountain
8 BMS SW Entry Fountain	21 SHS Staff Rm Faucet	34 SHE Gym Fountain
9 BMS Hall Rm 14 Fountain	22 SHS Hall Rm 19 Fountain	35 SHE Boys Locker Fountain
10 BMS Hall Rm 6 Fountain	23 SHS Lower Gym Fountain	36 SHE Girls Locker Fountain
11 BMS Kitchen Dish Faucet	24 SHS Boiler Rm Flush	37 SHE Boiler Rm Flush
12 BMS Kitchen Prep Faucet	25 SHS Concession Faucet	38 DO Kitchen Faucet
13 BMS Staff Rm Faucet	26 SHE Kitchen S Faucet	39 DO Supply Rm Faucet

Outlet Type:	WF	Water Fountain (not chilled)
	WC	Water Fountain (chilled)
	KF	Kitchen Faucet
	CF	Custodial Faucet
	HB	Hose Bib

Sample Type:	P	Primary Sample (first draw)
	F	Flush Sample (30 second pre-flush)

For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.



Professional
Laboratory
Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number: _____

Page 1 of 4

Client Contact Information		Results Reporting Information		Invoicing Information	
Company/Client Name: <u>Seaside School Dist 10</u>		Project Manager: <u>Chuck Lobezut</u>		Accounts Payable Contact:	
Address: <u>1801 S Franklin</u>		Mailing Address:		Mailing Address:	
City/State/Zip: <u>Seaside OR 97138</u>		City/State/Zip:		City/State/Zip:	
phone: <u>503-738-5591</u>		phone: <u>503-791-5190</u>		phone:	
fax or email: <u>503-738-3471</u>		fax or email: <u>CLobezut@Seaside-K12.0R.us</u>		fax or email:	

SAMPLING INFORMATION

Sampling Location:	P.O. #:	PWSID #:
Sampled By:	Project Name:	Permit #:

Send results to OR State Health Division? (Please circle) Yes No

Sample Specific Notes/Field Data for each WW sample, specify <u>Grab</u> / <u>Composite</u> for each DW sample, specify <u>Raw</u> / <u>Treated</u> , <u>Source</u> / <u>Distribution</u> , <u>Single</u> / <u>Combined</u> WHERE APPLICABLE										SEE ATTACHED									
Lab ID Lab use only	Sample Identification Please enter a unique ID per line for each separate sample	Date Collected	(Begin-End if comp.) Time Collected	Sample Matrix*	# of cont. rec'd														
	01 - 004 - WF - P	6/23/17	0543																
	02 - 004 - WF - P	"	0545																
	03 - 004 - WF - P	"	0548																
	04 - 004 - WF - P	"	0551																
	05 - 004 - WF - P	"	0553																
	06 - 004 - KF - P	"	0556																
	07 - 004 - HB - F	"	0558																
	08 - 006 - WF - P	"	0608																
	09 - 006 - WF - P	"	0613																
	10 - 006 - WF - P	"	0618																
Relinquished By (print):		Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:											
Relinquished By (print):		Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:											

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: _____ Date/Time: _____ Temp. on receipt: _____ °C On ice? Y N ID: TRM-10-_____

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Sample Specific Notes/Field Data
for each WW sample, specify Grab / Composite
for each DW sample, specify Raw / Treated,
Source / Distribution, Single / Combined
WHERE APPLICABLE



Professional
Laboratory
Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number: _____

Page 2 of 4

Client Contact Information		Results Reporting Information		Invoicing Information	
Company/Client Name: <u>Sepulveda School District</u>		Project Manager:		Accounts Payable Contact:	
Address:		Mailing Address:		Mailing Address:	
City/State/Zip:		City/State/Zip:		City/State/Zip:	
phone:		phone:		phone:	
fax or email:		fax or email:		fax or email:	

SAMPLING INFORMATION

Sampling Location:	P.O. #:	PWSID #:
Sampled By:	Project Name:	Permit #:
Send results to OR State Health Division? (Please circle) Yes No		

Lab ID Lab use only	Sample Identification	Please enter a unique ID per line for each separate sample	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested**										SEE ATTACHED	Sample Specific Notes/Field Data for each WW sample, specify <u>Grab</u> / <u>Composite</u> for each DW sample, specify <u>Raw</u> / <u>Treated</u> , <u>Source</u> / <u>Distribution</u> , <u>Single</u> / <u>Combined</u> WHERE APPLICABLE
	11-0006-KF-P		6/23/17	0623														
	12-0006-KF-P		"	0623														
	13-0006-KF-P		"	0625														
	14-0006-WF-P		"	0628														
	15-0007-KF-P		"	0656														
	16-0007-KF-P		"	0657														
	17-0007-WF-P		"	0702														
	18-0007-WF-P		"	0704														
	19-0007-KF-P		"	0706														
	20-0007-WF-P		"	0708														

Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)



Professional
Analytical
Laboratory
Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number: _____

Page 3 of 4

Client Contact Information		Invoicing Information	
Company/Client Name: <u>Seaside School Dist</u>		Accounts Payable Contact:	
Address:		Mailing Address:	
City/State/Zip:		City/State/Zip:	
phone:		phone:	
fax or email:		fax or email:	

SAMPLING INFORMATION

Sampling Location:	P.O. #:	PWSID #:
Sampled By:	Project Name:	Permit #:

Send results to OR State Health Division? (Please circle)	Yes	No
---	-----	----

Sample Specific Notes/Field Data for each WW sample, specify <u>Grab</u> / <u>Composite</u> for each DW sample, specify <u>Raw</u> / <u>Treated</u> , <u>Source</u> / <u>Distribution</u> , <u>Single</u> / <u>Combined</u> WHERE APPLICABLE										SEE ATTACHED									
Lab ID Lab use only	Sample Identification	Please enter a unique ID per line for each separate sample	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd													
		21 - 007 - KF - P	6/23/17	0711															
		22 - 007 - WF - P	"	0712															
		23 - 007 - WC - P	"	0715															
		24 - 007 - CF - P	"	0718															
		25 - 007 - KF - P	"	0721															
		26 - 005 - KF - P	"	0739															
		27 - 005 - KF - P	"	0740															
		28 - 005 - KF - P	"	0741															
		29 - 005 - WF - P	"	0743															
		30 - 005 - WF - P	"	0744															
Relinquished By (print):			Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:										
Relinquished By (print):			Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:										

Received by Laboratory Log-In Staff:		Date/Time:	Temp. on receipt: _____ °C	On ice? Y N
		Date/Time:	Containers Intact? Y N	ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.



Professional
Laboratory
Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number: _____

Page 4 of 4

Client Contact Information		Results Reporting Information		Invoicing Information	
Company/Client Name: <u>SPRINGFIELD SCHOOL DIST CO</u>		Project Manager:		Accounts Payable Contact:	
Address:		Mailing Address:		Mailing Address:	
City/State/Zip:		City/State/Zip:		City/State/Zip:	
phone:		phone:		phone:	
fax or email:		fax or email:		fax or email:	

SAMPLING INFORMATION

Sampling Location:	P.O. #:	PWSID #:
Sampled By:	Project Name:	Permit #:

Send results to OR State Health Division? (Please circle) Yes No

Analysis Requested**

SEE ATTACHED

Sample Specific Notes/Field Data
for each WW sample, specify Grab / Composite
for each DW sample, specify Raw / Treated,
Source / Distribution, Single / Combined
WHERE APPLICABLE

Lab ID	Sample Identification	Please enter a unique ID per line for each separate sample	Date Collected	Time Collected	Sample Matrix*	# of cont. rec'd	Analysis Requested**	SEE ATTACHED
	31-005-WF-P		6/23/17	0745				
	32-005-WF-P		"	0748				
	33-005-WF-P		"	0749				
	34-005-WF-P		"	0751				
	35-005-WF-P		"	0753				
	36-005-WF-P		"	0754				
	37-005-UB-P		"	0757				
	38-008-KF-P		"	0814				
	39-008-KF-P		"	0815				

Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2017

Received: 06/28/2017

Sampled By:

Work Order: 7179046

C L I E N T **Seaside School District**

Attn: Chuck Loesch

1801 S Franklin

Seaside OR, 97138

Phone: (503) 791-5190

Project:

Project # : N/A

Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7179046-01	Sample Name: 01 - 004 - WF - P Sampled: 6/23/17 5:43						Matrix: Water
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	07/10/17 14:51
7179046-02	Sample Name: 02 - 004 - WF - P Sampled: 6/23/17 5:45						Matrix: Water
+Lead	1030	EPA 200.9	10	ppb	2	20 ppb	07/10/17 14:51
7179046-03	Sample Name: 03 - 004 - WF - P Sampled: 6/23/17 5:48						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-04	Sample Name: 04 - 004 - WF - P Sampled: 6/23/17 5:51						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-05	Sample Name: 05 - 004 - WF - P Sampled: 6/23/17 5:53						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-06	Sample Name: 06 - 004 - KF - P Sampled: 6/23/17 5:56						Matrix: Water
+Lead	1030	EPA 200.9	10	ppb	2	20 ppb	07/10/17 14:51
7179046-07	Sample Name: 07 - 004 - HB - F Sampled: 6/23/17 5:58						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-08	Sample Name: 08 - 006 - WF - P Sampled: 6/23/17 6:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-09	Sample Name: 09 - 006 - WF - P Sampled: 6/23/17 6:13						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-10	Sample Name: 10 - 006 - WF - P Sampled: 6/23/17 6:18						Matrix: Water
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	07/10/17 14:51



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2017

Received: 06/28/2017

Sampled By:

Work Order: 7179046

C Seaside School District

L Attn: Chuck Loesch

I 1801 S Franklin

E Seaside OR, 97138

N Phone: (503) 791-5190

T

Project:


Project # : N/A

Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7179046-11	Sample Name: 11 - 006 - KF - P Sampled: 6/23/17 6:23						Matrix: Water
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	07/10/17 14:51
7179046-12	Sample Name: 12 - 006 - KF - P Sampled: 6/23/17 6:23						Matrix: Water
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	07/10/17 14:51
7179046-13	Sample Name: 13 - 006 - KF - P Sampled: 6/23/17 6:25						Matrix: Water
+Lead	1030	EPA 200.9	13	ppb	2	20 ppb	07/10/17 14:51
7179046-14	Sample Name: 14 - 006 - WF - P Sampled: 6/23/17 6:28						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-15	Sample Name: 15 - 007 - KF - P Sampled: 6/23/17 6:56						Matrix: Water
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	07/10/17 14:51
7179046-16	Sample Name: 16 - 007 - KF - P Sampled: 6/23/17 6:57						Matrix: Water
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	07/10/17 14:51
7179046-17	Sample Name: 17 - 007 - WF - P Sampled: 6/23/17 7:02						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-18	Sample Name: 18 - 007 - WF - P Sampled: 6/23/17 7:04						Matrix: Water
+Lead	1030	EPA 200.9	9	ppb	2	20 ppb	07/10/17 14:51
7179046-19	Sample Name: 19 - 007 - KF - P Sampled: 6/23/17 7:06						Matrix: Water
+Lead	1030	EPA 200.9	20	ppb	2	20 ppb	07/10/17 14:51 MCL
7179046-20	Sample Name: 20 - 007 - WF - P Sampled: 6/23/17 7:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2017

Received: 06/28/2017

Sampled By:

Work Order: 7179046


C Seaside School District
L Attn: Chuck Loesch
I 1801 S Franklin
E Seaside OR, 97138
N Phone: (503) 791-5190
T

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7179046-21	Sample Name: 21 - 007 - KF - P Sampled: 6/23/17 7:11						Matrix: Water
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	07/10/17 14:51
7179046-22	Sample Name: 22 - 007 - WF - P Sampled: 6/23/17 7:12						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-23	Sample Name: 23 - 007 - WC - P Sampled: 6/23/17 7:15						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-24	Sample Name: 24 - 007 - CF - P Sampled: 6/23/17 7:18						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/10/17 14:51
7179046-25	Sample Name: 25 - 007 - KF - P Sampled: 6/23/17 7:21						Matrix: Water
+Lead	1030	EPA 200.9	32	ppb	2	20 ppb	07/10/17 14:51 MCLE
7179046-26	Sample Name: 26 - 005 - KF - P Sampled: 6/23/17 7:39						Matrix: Water
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	07/10/17 14:51
7179046-27	Sample Name: 27 - 005 - KF - P Sampled: 6/23/17 7:40						Matrix: Water
+Lead	1030	EPA 200.9	12	ppb	2	20 ppb	07/10/17 14:51
7179046-28	Sample Name: 28 - 005 - KF - P Sampled: 6/23/17 7:41						Matrix: Water
+Lead	1030	EPA 200.9	20	ppb	2	20 ppb	07/10/17 14:51 MCL
7179046-29	Sample Name: 29 - 005 - WF - P Sampled: 6/23/17 7:43						Matrix: Water
+Lead	1030	EPA 200.9	14	ppb	2	20 ppb	07/10/17 14:51
7179046-30	Sample Name: 30 - 005 - WF - P Sampled: 6/23/17 7:44						Matrix: Water
+Lead	1030	EPA 200.9	46	ppb	4	20 ppb	07/10/17 14:51 MCLE



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

Professional Laboratory Services

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2017
Received: 06/28/2017
Sampled By:
Work Order: 7179046

C
L
I
E
N
T
Seaside School District
Attn: Chuck Loesch
1801 S Franklin
Seaside OR, 97138
Phone: (503) 791-5190

Project:
Project # : N/A
Sample Type :

Sampling Location:

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7179046-31	Sample Name: 31 - 005 - WF - P Sampled: 6/23/17 7:45						Matrix: Water
+Lead	1030	EPA 200.9	10	ppb	2	20 ppb	07/10/17 14:51
7179046-32	Sample Name: 32 - 005 - WF - P Sampled: 6/23/17 7:48						Matrix: Water
+Lead	1030	EPA 200.9	25	ppb	2	20 ppb	07/10/17 14:51 MCLE
7179046-33	Sample Name: 33 - 005 - WF - P Sampled: 6/23/17 7:49						Matrix: Water
+Lead	1030	EPA 200.9	12	ppb	2	20 ppb	07/10/17 14:51
7179046-34	Sample Name: 34 - 005 - WF - P Sampled: 6/23/17 7:51						Matrix: Water
+Lead	1030	EPA 200.9	14	ppb	2	20 ppb	07/13/17 13:58
7179046-35	Sample Name: 35 - 005 - WF - P Sampled: 6/23/17 7:53						Matrix: Water
+Lead	1030	EPA 200.9	24	ppb	2	20 ppb	07/13/17 13:58 MCLE
7179046-36	Sample Name: 36 - 005 - WF - P Sampled: 6/23/17 7:54						Matrix: Water
+Lead	1030	EPA 200.9	25	ppb	2	20 ppb	07/13/17 13:58 MCLE
7179046-37	Sample Name: 37 - 005 - HB - P Sampled: 6/23/17 7:57						Matrix: Water
+Lead	1030	EPA 200.9	34	ppb	2	20 ppb	07/13/17 13:58 MCLE
7179046-38	Sample Name: 38 - 008 - KF - P Sampled: 6/23/17 8:14						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/13/17 13:58
7179046-39	Sample Name: 39 - 008 - KF - P Sampled: 6/23/17 8:15						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/13/17 13:58

MCL This analyte is at the Maximum Contamination Limit

MCLE This analyte exceeds the MCL limit.



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 07/14/2017

Received: 06/28/2017

Sampled By:

Work Order: 7179046

C L I E N T Seaside School District

Attn: Chuck Loesch

1801 S Franklin

Seaside OR, 97138

Phone: (503) 791-5190

Project:

Project # : N/A

Sample Type :

Sampling Location:


Lab Number

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.