



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

<p>Violation #2. Playground, Equipment &amp; Athletic Fields Sand spurs observed around playground area. Should be cut before students return to avoid injury. CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5 (2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.</p>
<p>Violation #5. Maintenance &amp; Repair Some windows are rusted and cracked. Should be repainted and cracked windows replaced. Some floors are in disrepair and require maintenance. CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components &amp; finishes shall be kept clean &amp; in good repair.</p>
<p>Violation #13. Handwashing Facilities Several bathrooms did not have hot water provided. Both hot and cold water must be provided. CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.</p>
<p>Violation #18. Drinking Fountains Several water fountains were out of operation and need to be prepared. CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned &amp; disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational &amp; ancillary facilities shall have drinking fountains for all occupants, in ratios &amp; accessible as required.</p>

Inspection Conducted By: Jared Williams (35264)  
Inspector Contact Number: Work: (863) 519-8330 ex.  
Print Client Name: Shay Hixenbaugh  
Date: 7/23/2020

Inspector Signature:

Handwritten signature of Jared Williams.

Client Signature:

Handwritten signature of the client.